

Abstract

CONF-830901--3

ON-LINE PREDICTION OF BWR TRANSIENTS IN SUPPORT
OF PLANT OPERATION AND SAFETY ANALYSES*

W. Wulff, H. S. Cheng, S. V. Lekach, and A. N. Mallen
Plant Analyzer Development Group
Brookhaven National Laboratory
Upton, New York 11973 U.S.A.

BNL-NUREG--32914

DE83 011644

A combination of advanced modeling techniques and modern, special-purpose peripheral minicomputer technology is presented which affords realistic predictions of plant transient and severe off-normal events in LWR power plants through on-line simulations at a speed ten times greater than actual process speeds. Results are shown for a BWR plant simulation.

The mathematical models account for nonequilibrium, nonhomogeneous two-phase flow effects in the coolant, for acoustical effects in the steam line and for the dynamics of the recirculation loop and feed-water train. Point kinetics incorporate reactivity feedback for void fraction, for fuel temperature, and for coolant temperature. Control systems and trip logic are simulated for the nuclear steam supply system.

The AD-10 of Applied Dynamics International is the special-purpose peripheral processor. It is specifically designed for high-speed digital system simulation, accommodates hardware (instrumentation) in the input/output loop, and operates interactively on-line, like an analog computer.

Results are shown to demonstrate computing capacity, accuracy, and speed. Simulation speeds have been achieved which are one hundred and ten times larger than those of a CDC-7600 main-frame computer or ten times greater than real-time speed.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

*Work performed under the auspices of the U.S. Nuclear Regulatory Commission.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

SUMMARY

ON-LINE PREDICTION OF BWR TRANSIENTS IN SUPPORT OF PLANT OPERATIONS*

W. Wulff, H. S. Cheng, S. V. Lekach and A. N. Mallen (BNL)

INTRODUCTION

Nuclear power plant simulations utilizing recently developed thermohydraulics codes such as TRAC and RELAP-5, are affordable only in a limited way to a few large institutions with access to major, government-supported computing centers.

This paper demonstrates the feasibility of simulating plant transients and severe abnormal transients in nuclear power plants at much faster than real-time computing speeds in a low-cost, dedicated, interactive minicomputer. This is achieved by implementing advanced modeling techniques in modern, special-purpose peripheral processors for high-speed system simulation. The results of this demonstration will impact safety analyses and parametric studies, studies on operator responses and control system failures and, most importantly, they will establish the capability for the continuous on-line monitoring of plant performance and the detection and diagnosis of system or component failures. Moreover, the high-speed simulation capability of the developed interactive system is suitable for mitigating effectively the consequences from accidents by predicting the outcome of operator actions before they are taken.

Crucial to the time-critical nuclear power plant simulation is the simulation of the Nuclear Steam Supply System (NSSS). The feasibility demonstration reported here consists (i) of implementing, on the AD-10 minicomputer, an

*Work performed under the auspices of the U.S. Nuclear Regulatory Commission.

advanced thermohydraulics model for the NSSS dynamics in a BWR system, (ii) of comparing the computed results from the minicomputer with those of a large CDC-7600 main-frame computer, executing the same thermohydraulics model, and (iii) of establishing thereby computing accuracy and speed. The computing capability is further demonstrated for selected transients caused by control system failures.

SIMULATION TECHNIQUES

Mathematical Models. Effective simulation of two-phase flow is achieved in part by matching flow model complexity with available detail of empirical information for constitutive relations. Thus, a four-equation model was chosen to predict one-dimensional, nonhomogeneous, nonequilibrium two-phase flow. Only two, namely the vapor mass and the mixture energy conservation equations, are integrated as partial differential equations by volume-averaging over each of the 55 computational cells in the system and by integrating the resulting ordinary differential equations with respect to time. The third equation, the mixture mass balance, is analytically converted into a volume flux divergence equation and simply integrated along the flow paths by numerical means. The fourth equation, the momentum balance, is analytically integrated along closed contours through each of the three core channels and through the recirculation loop. The resulting contour momentum balances are ordinary differential equations and integrated to yield the individual loop momenta. A single, system-averaged pressure is computed from global mass and energy equations and used to predict thermophysical coolant properties everywhere. This and the contour integration of the momentum balance affords the computational decoupling of the momentum balance from mass and energy balances while retaining completely the effects of gravity on the momentum balance.

Relative phasic velocities are computed from the slip model by Bankoff-Jones¹. Nonequilibrium vapor generation is modeled in two parts, one for wall heating and the other for flashing and condensing. Standard correlations² are employed for nonboiling and boiling wall heat transfer. Form losses and two-phase flow effects for wall shear are accounted for. Polynomial fits are used to represent thermophysical and transport properties.

Acoustic effects in the steam lines are computed with a dynamic model for adiabatic compressible vapor. The radial and axial fuel temperature distributions are predicted from a lumped-parameter model for each of the 12 axial flow channel segments. A point kinetics model is used first to start the simulation program and will be replaced later by one-dimensional transient neutron kinetics predictions.

Model selection and its analytical optimization, as described above, contribute significantly to the simulation efficiency. The special features of the peripheral processor employed require scaling and suggest the use of high-speed table interpolation. Scaling and precomputing of multi-dimensional table entries reduced sharply the required number of arithmetic operations during simulation and thusly increased even further the simulation efficiency.

Special-Purpose Computer. The selected parallel processor AD-10 of Applied Dynamics International has been specifically designed for fast, efficient integration of ordinary differential equations. This special-purpose peripheral processor is being programmed through a PDP-11/34 host computer, by using the high-level, modular state-equation oriented simulation language MPS-10. The AD-10 processor can interact directly with other digital computers (array processors or general-purpose computers), with instrumentation, color-graphics terminals, recorders, oscilloscopes or with other AD-10 processors. Each AD-10 provides for up to 128 on-line interactive channels for I/O transmission.

The AD-10 processor has six synchronized (10 MHz), special-purpose microprocessors for arithmetic and logical operations, each equipped with its own instructional memory and executing in parallel while broadcasting data to each other and to interleaved data memory via a 20 MHz Multibus.

The computing speed in the AD-10 processor is due primarily to its architecture; namely, the parallel processing in six microprocessors, pipe-line architecture (seven stages in the Arithmetic Processor ARP), the interleaving of data memory, synchronous broadcasting of data, hard-wired arithmetic for function generation and a combination of fixed and floating point arithmetic with 16- and 48-bit word lengths. Computing speed is also accelerated by the use of efficient integration algorithms and multi-dimensional table interpolations which eliminate a large number of arithmetic operations without loss of accuracy.

RESULTS

The feasibility demonstration performed at BNL showed that the AD-10 can simulate a licensing base transient ten times faster than the transient proceeds and more than 100 times faster than the CDC-7600 main-frame computer which utilized also the benefits from converting the partial differential equations of mixture mass and momentum balances into volume flux divergence and contour momentum equations, respectively.

One reference transient is a turbine trip from full power, followed by reactor scram, but aggravated by disabled control circuitry for steam bypass, for safety and relief valves and for recirculation pump trips. The frequency and amplitude characteristics of this transient are typical of most plant transients and abnormal events and therefore typical of the integration step size limitation which is most frequently imposed by boundary conditions and system responses.

Computing Capacity. The 55-node, four-equation model formulation for the NSSS thermohydraulics required half of the currently available instructional memory of one AD-10 processor. A second processor has been dedicated to simulate, in parallel, neutron kinetics, conduction and systems controls.

Computing Accuracy was established³ by comparing results from the AD-10 with those of the CDC-7600 main-frame computer. The agreement is approximately within $\pm 3\%$. The adequacy of 15-bit precision for computing derivatives was established by comparing the full 15-bit precision results with computations obtained with 13- and 14-bit precision. No differences could be detected.

Computing Speed. The AD-10 requires 78 microseconds per integration step, the CDC-7600 required two milliseconds for the same task. The AD-10 is ten times faster than real-time and 110 times faster than the CDC-7600. The overall speed multiplier of 110 is composed of a factor between three and five due to analytical model optimization and function generation, and a factor between approximately 20 and 50 entirely due to the features of the AD-10, including its interactive capabilities.

CONCLUSIONS

Modern, special-purpose peripheral processors are fast, accurate and cost-effective to outperform large main-frame computers in the simulation of transients in nuclear power plants. Thus, the technology is feasible to support plant operation with computer-generated information, specifically for the mitigation of consequences from accidents.

REFERENCES

1. A. B. Jones and D. G. Dight, "Hydrodynamic Stability of a Boiling Channel", KAPL-2208, Knolls Atomic Power Laboratory (1962).
2. J. G. Collier, "Convective Boiling and Condensation", McGraw-Hill, Second Edition (1981) p. 214.
3. W. Wulff, "Plant Analyzer Development Program" in Safety Research Programs sponsored by the Office of Nuclear Regulatory Research", Quarterly Progress Report, compiled by A. J. Weiss, BNL-NUREG-51454, NUREG/CR-2331, Vol. 2, No. 3, Chapter 5 (September 1982).