

JAN 04 1995

ENGINEERING DATA TRANSMITTAL

1. EDT 602374

36

70

2. To: (Receiving Organization) Information Release	3. From: (Originating Organization) TWR/CP (MWTF)	4. Related EDT No.: N/A
5. Proj./Prog./Dept./Div.: W-236A (MWTF)	6. Cog. Engr.: ME Hughes	7. Purchase Order No.: N/A
8. Originator Remarks:		9. Equip./Component No.: N/A
		10. System/Bldg./Facility: N/A
11. Receiver Remarks:		12. Major Assm. Dwg. No.: N/A
		13. Permit/Permit Application No.: N/A
		14. Required Response Date: N/A

15. DATA TRANSMITTED					(F)	(G)	(H)	(I)
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	Approval Designator	Reason for Transmittal	Originator Disposition	Receiver Disposition
1	WHC-SD-W236A-TI-008	- - -	- ① -	Position Paper, W236A/MWTF - Tank Ventilation System Design Air Flow Rates	SQ	1,2		

16. KEY					
Approval Designator (F)		Reason for Transmittal (G)		Disposition (H) & (I)	
E, S, Q, D or N/A (see WHC-CM-3-5, Sec.12.7)		1. Approval	4. Review	1. Approved	4. Reviewed no/comment
		2. Release	5. Post-Review	2. Approved w/comment	5. Reviewed w/comment
		3. Information	6. Dist. (Receipt Acknow. Required)	3. Disapproved w/comment	6. Receipt acknowledged

17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)											
(G)	(H)	(J) Name	(K) Signature	(L) Date	(M) MSIN	(J) Name	(K) Signature	(L) Date	(M) MSIN	Reason	Disp.
1,2	1,0 ^{mt}	Cog. Eng. - ME Hughes	<i>[Signature]</i>	13 Dec 94	134-08						
1,2	1,0 ^{mt}	Cog. Mgr. - RL Fritz	<i>[Signature]</i>	13 Dec 94	134-08						
1,2		QA - LR Hall	<i>[Signature]</i>	13/13/94	134-08						
1,2		Safety - SE Chalk	<i>[Signature]</i>	13/14/94	134-08						
		OSTI (2)		13-07							

18. ME Hughes <i>[Signature]</i> Signature of EDT Originator	13 Dec 94 Date	19. ME Hughes <i>[Signature]</i> Authorized Representative for Receiving Organization	13 Dec 94 Date	20. RL Fritz <i>[Signature]</i> Cognizant Manager	13 Dec 94 Date	21. DOE APPROVAL (if required) Ctrl. No. N/A <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/comments <input type="checkbox"/> Disapproved w/comments
--	-------------------	---	-------------------	---	-------------------	---

BD-7400-172-2 (04/94) GEF097

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

JR

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

RELEASE AUTHORIZATION

Document Number: WHC-SD-W236A-TI-008 Rev. 0

Document Title: Position Paper - Tank Ventilation System Design Air Flow Rates

Release Date: January 4, 1995

This document was reviewed following the procedures described in WHC-CM-3-4 and is:

APPROVED FOR PUBLIC RELEASE

WHC Information Release Administration Specialist:

V. L. Birkland

V.L. Birkland

January 4, 1995

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

This report has been reproduced from the best available copy. Available in paper copy and microfiche. Printed in the United States of America. Available to the U.S. Department of Energy and its contractors from:

U.S. Department of Energy
Office of Scientific and Technical Information (OSTI)
P.O. Box 62
Oak Ridge, TN 37831
Telephone: (615) 576-8401









Available to the public from:

U.S. Department of Commerce
National Technical Information Service (NTIS)
5285 Port Royal Road
Springfield, VA 22161
Telephone: (703) 487-4650

SUPPORTING DOCUMENT		1. Total Pages <i>6</i> 7
2. Title Position Paper - Tank Ventilation System Design Air Flow Rates	3. Number WHC-SD-W236A-TI-008	4. Rev No. 0
5. Key Words TANKS, MWTF, POSITION PAPER, VENTILATION SYSTEM	6. Author Name: GK Boolsby <i>[Signature]</i> Signature Organization/Charge Code 7F220	
7. Abstract Position Paper to develop and document a position on the air flow rates for the ventilation system for the waste storage tanks being designed by the Multi-Function Waste Tank Facility project.		
8. RELEASE STAMP <div style="border: 1px solid black; padding: 10px; text-align: center;"> <p>OFFICIAL RELEASE BY W-236A IMT</p> <p>DATE JAN 04 1995</p> <p>STATION (36) CLERK (70)</p> </div>		

~~W236A-TI-PP4~~

Position Paper
Project W236A
Multi-Function Waste Tank Facility
Tank Ventilation System Design Air Flow Rates

Prepared By:		4/29/94
	G. K. Goolsby, ICF KH/HVAC Engineering Discipline	Date
Concurrence:		5/1/94
	G. G. Renfro, WHC/Mgr., MWTF Project Engineering	Date
Concurrence:		5/2/94
	J. M. Light, WHC/Mgr., MWTF Tech. Studies/Proj. Int.	Date
Concurrence:		5/3/94
	T. B. McCall, WHC/Mgr., Thermal Hydraulics Analysis	Date
Concurrence:		4/29/94
	T. C. Oten, ICF KH/MWTF Engineering Manager	Date
Concurrence:		5-2-94
	J. R. Nicholson, ICF KH/MWTF Consulting Engineer	Date
Concurrence:		5-2-94
	J. D. Cloud, ICF KH/MWTF Project Manager	Date
Concurrence:		5/2/94
	R. L. Fritz, WHC/MWTF Project Manager	Date

~~W236A-TI-PP4~~

Position Paper
Project W-236A
Multi-Function Waste Tank Facility
Tank Ventilation System Design Air Flow Rate

1.0 Purpose

The purpose of this paper is to document a project position on required ventilation system design air flow rates for the waste storage tanks currently being designed by project W-236A, the Multi-Function Waste Tank Facility (MWTF).

2.0 Background

The Title I design primary tank heat removal system consists of two systems:

- 1) A primary tank vapor space ventilation system
- 2) An annulus ventilation system

At the conclusion of Title I design, air flow rates for the primary and annulus ventilation systems were 960 scfm and 4400 scfm, respectively, per tank (ref 1). These design flow rates were capable of removing 1,250,000 Btu/hr from each tank (ref 2). However, recently completed and ongoing studies have resulted in a design change to reduce the extreme case heat load to 700,000 Btu/hr. This revision of the extreme case heat load, coupled with results of scale model evaporative testing performed by WHC Thermal Hydraulics (ref 3), allow for a reduction of the design air flow rates for both primary and annulus ventilation systems.

MASTER

3.0 Discussion

The air flow rates for both the primary and annulus ventilation systems are determined by the heat removal requirements. The revised extreme case heat removal requirements (ref 4) are listed as follows:

- Mixer Pump 382,500 Btu/hr
- Radionuclide 250,000 Btu/hr
- Contingency 67,500 Btu/hr
- Total 700,000 Btu/hr

These reduced heat loads allow for lower air flow rates through both the primary and annulus ventilation systems. Required air flow rates for the MWTF design were determined using empirical correlations (ref 5). The empirical correlations were modified using evaporation rate data obtained from tank scale model testing provided by WHC Thermal Hydraulics. The empirical correlations are incorporated into a computer code originally developed for analysis of the 241-AZ tank ventilation system (ref 5). Computer code verification of the empirical correlations will be performed as part of the Title II design effort. Preliminary analysis using modified empirical correlations specify that approximately 455 scfm of primary ventilation air flow is required to maintain the tank waste temperature at 190°F using the following inputs:

- Heat load 700,000 Btu/hr
- Design inlet air temperature 77° F
- Design relative humidity 40% RH
- Annulus air flow 1,100 scfm

~~W236A-TI-PP4~~

A safety factor of approximately 10% was applied to the primary air flow rate (455 scfm), as predicted by the modified empirical equations. This results in a maximum design air flow rate for the primary ventilation system of 500 scfm (an approximately 48% reduction from the Title I design air flow rate of 960 scfm). This reduction in the design heat load allows for a larger proportion of the total heat removal to be performed by the primary ventilation system (as opposed to the annulus ventilation system). With an air flow of 500 scfm, the primary ventilation system will be able to remove approximately 605,000 Btu/hr without assistance from the annulus ventilation system.

ICF KH selected a maximum design air flow rate of 1,100 scfm for the annulus ventilation system to enable the primary ventilation system air flow rate to be regulated to a maximum of 500 scfm. The annulus design air flow reduction from the Title I design rate of 4400 scfm to 1100 scfm allows for the removal of the annulus circular header, distribution piping, and the annulus supply fans, and for the downsizing of the annulus system.

Design air flow rates for the heat removal system are based on the ability to provide adequate cooling at the extreme case heat load (as defined in ref 4). Limited control of tank waste temperature at the nominal heat load (ref 4) is possible using variable air volumes in the ventilation systems.

~~W236A-TI-PP4~~

4.0 Conclusions and Recommendations

Based on the preceding discussion, ICF Kaiser Hanford Co. (ICF KH) concludes that the design should incorporate the following design air flow rates:

- Primary ventilation system: 500 scfm maximum
- Annulus ventilation system: 1100 scfm maximum.

In addition, the minimum air flow rates in the primary and annulus ventilation systems will be investigated during Title II design. The results of the Title II investigation will determine the range of available temperature control using variable air flows to both ventilation systems.

~~W236A-TI-PP4~~

5.0 References

1. Title I Design Report, *Multi-Function Waste Tank Facility*, WHC-SD-W236A-RPT-002, Rev. 0, prepared by ICF Kaiser Hanford Company, February 1994.
2. Functional Design Criteria, *Multi-Function Waste Tank Facility*, WHC-SD-W236A-FDC-001, Rev. 1, prepared by Westinghouse Hanford Company, October 1993 (draft).
3. Internal Memo, B. A. Crea (WHC Thermal Hydraulics) to J. M. Light (WHC), *Design Values from the Evaporation Test*, 7E870-BAC-94-045, April 11, 1994.
4. Groth, B. D. , Position Paper, *Project W-236A Tank Heat Loading*, Rev. 1. March 30, 1994.
5. *Analysis of Tank Bump Potential During In-Tank Washing Operations Proposed for the 241-AZ Tanks*, WHC-SD-W-E-114 Rev. 0; prepared by Westinghouse Hanford Company, (date).