

CU9600406

45-96



CU9600406

CIEN-R

EPITHERMAL NEUTRON FLUX CHARACTERIZATION OF THE FANCA
MARK III REACTOR, SALAZAR, MEXICO, FOR USE IN IAEA

Diaz Rizo, O.; Herrera Peraza, M.C.;
Alvarez Ballon, I.
Lopez Reyes, M.C.
Manzo Guevara, M.V.
Ixquiac Cabrera, M.

*
**

- * Instituto Superior de Ciencias y Tecnologías Nucleares. La Habana, Cuba
- ** Instituto Nacional de Investigaciones Nucleares Mexico DF, Mexico
- *** Centro de Isotopos. La Habana, Cuba
- **** Universidad de San Carlos, Guatemala

La Habana, Cuba
1996

POOR QUALITY ORIGINAL

VOL 28 No 03

EPITHERMAL NEUTRON FLUX CHARACTERIZATION OF THE TRIGA MARK III REACTOR, SALAZAR, MEXICO, FOR USE IN INAA

**O. DIAZ RIZO, E. HERRERA PERAZA, M.C. LOPEZ REYES¹,
I. ALVAREZ BELLON, M.V.MANSO GUEVARA², M. IXQUIAC CABRERA***

High Institute for Nuclear Sciences and Technology
Ave. Salvador Allende, esq. Luaces, Havana, Cuba

¹ *National Nuclear Research Institute*
Carr. México-Toluca, km 36½ Salazar, México D.F..

² *Isotopes Center*
Autopista Nacional, km 3½, Pedro Pi, Havana, Cuba

Submitted to: Journal Radioanalytical and Nuclear Chemistry. Letters

Subject categories: **E 3600**

Key-words: ***neutron flux: q1, neutron activation analysis, triga type reactors: m1, Mexico.***

* Permanent adress: *San Carlos University, Guatemala City.*

EPITHERMAL NEUTRON FLUX CHARACTERIZATION OF THE TRIGA MARK III REACTOR, SALAZAR, MEXICO, FOR USE IN INAA.

O. DIAZ RIZO, E. HERRERA PERAZA, M.C. LOPEZ REYES¹,
I. ALVAREZ BELLON, M.V.MANSO GUEVARA², M. IXQUIAC CABRERA*.

High Institute for Nuclear Sciences and Technology
Ave. Salvador Allende, esq. Luaces, Havana, Cuba.

¹ *National Nuclear Research Institute.*
Carr. México-Toluca, km 36½ Salazar, México D.F.

² *Isotopes Center*
Autopista Nacional, km 3½. Pedro Pl, Havana, Cuba

The nonideality of the epithermal neutron flux distribution at a reactor site parameter (α) the thermal-to-epithermal neutron ratio (f) were determined in the 3 typical irradiation positions of the TRIGA MARK III reactor of the National Nuclear Research Institute, Salazar, Mexico, using the "Cd-ratio for multimonitor" and "bare bi-isotopic monitor" -methods respectively. This characterization is of use in the K_0 -method of NAA, recently introduced at the Institute.

INTRODUCTION

When applying the K_0 -method of instrumental (n, γ) activation analysis with reactor neutrons (INAA), it is found that the general accepted $1/E_n$ - epithermal neutron flux distribution is often not satisfactory from the standpoint of the analysis accuracy [1]. Better is the use of the semiempirical representation [2,3]

$$\phi_e(E_n) \sim 1/E_n^{1+\alpha}$$

whose proved to be satisfactory for INAA needs [4] and where α is a measure of the epithermal flux deviation from the ideal, and is a characteristic of the reactor irradiation position. Both positive and negative α -values are reported in the literature [5], corresponding to "softened" and a "hardened" epithermal spectrum, as compared to the ideal one. This is illustrated in Fig 1

* Permanent adress: *San Carlos University, Guatemala City.*




Fig. 1.-Epithermal spectrum nonideality.

The $1/E^{1+\alpha}$ representation enables easy correction of the resonance integral (and hence of the analytical result) for the deviating epithermal spectrum [4]. Thus, when calculating the concentration of an element in a sample, α should be known to preserve the accuracy of the analysis.

With the same aim, the thermal (subcadmium)-to-epithermal ratio - $f = \Phi_{th}/\Phi_e$ must be well known [6]. The designation "subcadmium" refers to the definition of Φ_{th} , the conventional thermal fluence rate, as $\Phi_{th} = n_s v_0$ where v_0 is the 2200 m.s^{-1} neutron velocity and n_s is the "subcadmium" neutron density up to 0.55 eV neutron energy. On the other hand, Φ_e is the conventional epithermal neutron fluence rate, defined as the true epithermal neutron fluence rate per unit $\ln E$ interval. The use of f is strictly associated with Q_0 (the resonance integral to 2200 ms^{-1} cross section ratio), both parameters being linked to the Hagdahl convention [7] upon which the application of the K_0 -method is based.

DETERMINATION OF α AND f VALUES.

The parameter α can be obtained [8] as the slope ($-\alpha$) of the straight line when plotting $\log(T_r)$ versus $\log(E_r/1 \text{ eV})$, which comes to the same as solving the implicit equation (1 eV omitted):

$$\alpha + \frac{\sum_1^N \left[\log(E_{r,i}) - \frac{\sum_1^N \log(E_{r,i})}{N} \right] \left[\log(T_i) - \frac{\sum_1^N \log(T_i)}{N} \right]}{\sum_1^N \left[\log(E_{r,i}) - \frac{\sum_1^N \log(E_{r,i})}{N} \right]^2} = 0$$

where N is the number of coirradiated α -monitors, $E_{r,i}$ - the average resonance energy of the monitor i and T_i is given by the following expressions:

- In the "Cd-ratio for multi-monitor" method (A):

$$T_i = \frac{E_{r,i}^\alpha}{(F_{Cd} R_{Cd} - 1) Q_{0,j}(\alpha) G_{e,j} G_{th,j}}$$

where F_{Cd} - is the cadmium transmission factor for epithermal neutrons, R_{Cd} - the cadmium ratio and G_e and G_m - the correction factors for epithermal and thermal neutron self-shielding, respectively.

- In the "Cd-covered multi-monitor"-method (B):

$$T_i = \frac{(E_{r,i})^\alpha (A_{sp,j})_{Cd}}{k_{0,Au}(i) \epsilon_{p,j} F_{Cd} Q_{0,j}(\alpha) G_{e,j}}$$

with $A_{sp} = (N_p/t_m)/SDCw$, where N_p - measured net peak area, t_m - counting time, S - saturation factor, D - decay factor, C - counting factor and w - sample mass (in grams). $k_{0,Au}$ - tabulated k_0 -factors [9,10].

- In the "bare multi-monitor"-method (C):

$$T_i = (E_{r,i})^\alpha \frac{A_{sp,j} k_{0,Au}(i) \epsilon_{p,j} - A_{sp,N+1} k_{0,Au}(N+1) \epsilon_{p,N+1}}{Q_{0,j}(\alpha) G_{e,j} G_{th,j} - Q_{0,N+1}(\alpha) G_{e,N+1} G_{th,N+1}}$$

where "N+1" is an additionally coirradiated monitor and ϵ_p - is the experimental detector energy efficiency for the monitor γ -line.

After the knowledge of the epithermal spectrum shape factor α , the thermal-to-epithermal neutron flux ratio can be determined by Cd-ratio method [11] as:

$$f = (F_{Cd} R_{Cd} - 1) \cdot G_e \cdot Q_0(\alpha) / G_m$$

A proven technique for in-situ f -determination is the "bare bi-isotopic monitor"-method using Zr [12], according to:

$$f = \frac{G_{e,1} k_{0,Au}(1) \epsilon_{p,1} Q_{0,1}(\alpha) - G_{e,2} A_{sp,1} Q_{0,2}(\alpha)}{G_{ih,2} A_{sp,1} - G_{ih,1} k_{0,Au}(1) \epsilon_{p,1}} - \frac{A_{sp,2}}{A_{sp,1}}$$

were 1 = $^{97}\text{Zr}/^{97\text{m}}\text{Nb}$ (743 keV), 2 = ^{95}Zr (724.2 + 756.7 keV), and $\epsilon_{p,1} = \epsilon_{p,2}$. Due to the single-decayed gamma lines, it is allowed to position the Zr monitor as close as possible to the detector cap.

EXPERIMENTAL AND RESULTS.

In this work we investigate α and f in the three characteristic irradiation channels of the Triga Mark III reactor (Fig.2), i.e., in the "central channel" (CC), in the "pneumatic transfer tube channel" (PT) and in the position No.8 of the "SIFCA" (fixed system for the large irradiation).




Figure 2. - Ground plan of the 1 MW Triga Mark III reactor.

Thin high pure for analysis foils we use as α -monitors to minimize self-shielding effects (0.125 mm Zr, 0.125 mm Au, 0.05 mm Co, 0.125 mm Zn, 10 μ m Sn). Relevant nuclear data for the nuclides chosen as monitors are given in Table 1. So as to obtain good statistics on A_0 values, the irradiation were repeated 5 times. Five minutes irradiation were performed in CC and PT and 20 minutes in SIFCA. After appropriate cooling times, γ -activities were measured on a HPGe (ORTEC, 1.8 keV for 1332 keV line of ^{60}Co). Efficiency and monitor spectra were processed using the Spectrum Analyzer system [13].

Table 1
Nuclear data for the nuclides chosen as monitors [9,10]

Monitor	E_γ , eV	Q_0	F_{Cd}	γ -line, keV	$T_{1/2}$
$^{197}\text{Au}(n,\gamma)^{196}\text{Au}$	5.65 ± 0.40	15.7 ± 0.28	0.991	411.8	2 695 d
$^{59}\text{Co}(n,\gamma)^{60}\text{Co}$	136 ± 7	1.990 ± 0.054	1	1173.0	5.271 y
$^{112}\text{Sn}(n,\gamma)^{113m}\text{Sn}$	107.3 ± 0.7	48.4 ± 0.4	1	391.7	115.1 d
$^{96}\text{Zr}(n,\gamma)^{97}\text{Zr}$	338 ± 7	248.0 ± 0.4	1	743.6	16.74 h
$^{68}\text{Zn}(n,\gamma)^{69m}\text{Zn}$	529 ± 10	3.19 ± 0.18	1	438.6	13.76 h
$^{64}\text{Zn}(n,\gamma)^{65}\text{Zn}$	2560 ± 260	1.908 ± 0.094	1	1115.5	244.0 d
$^{94}\text{Zr}(n,\gamma)^{95}\text{Zr}$	6260 ± 250	5.05 ± 0.10	1	(724.2 + 756.7)	64.033 d

Table 2 shows the obtained results for Cd-ratio method. Average values and all statistic processing was performed using the BABXEL system. The quoted uncertain are calculated according to the error propagation study given in [8]. Trough relatively high (≈ 10 -30%), such inherent α -uncertainties are satisfactory for NAA needs, due to the large error reduction factor when calculating the concentration in the absolute or a single comparator method [4]. In this respect, large relative uncertainties are acceptable for lower absolute α 's.

Table 2
 α and f -values determined in the irradiation positions of the TRIGA MARK III reactor.

Channel	α (meth.A)	α [15]	f (bare)	f [15]
CC	-0.13 ± 0.01	-0.12 ± 0.02	29 ± 2	35 ± 2
PT	-0.14 ± 0.01	-0.11 ± 0.02	40 ± 2	40 ± 3
SIFCA	-0.08 ± 0.02	-0.07 ± 0.02	64 ± 3	58 ± 4

Negative α -values correspond to a "hardened" (poorly thermalized) epithermal spectrum, which is indeed to be expected due to the reactor configuration and to a relatively high (70%) ^{235}U enrichment in the fuel elements [14].


The comparison with a preliminar determination of α and f in 1994 [15] shows good coincidence. The practically non-variation of α and f -values in that long reactor exploitation period (without reactor recharge) is relevant. A more detailed study of the neutron flux characteristics of the Triga Mark III reactor, Salazar, for use in INAA is in preparation.

ACKNOWLEDGEMENTS

The authors are grateful to the Consejo Nacional de Ciencia y Técnica (CONACyT) and National Nuclear Research Institute from Mexico for the partial financial support of this research. Thanks are due to the NNRI reactor group for their help during the experiments.

REFERENCES

1. F. DE CORTE, L. MOENS, A. SIMONITS, K. SORDO-EL HAMMAMI, A. DE WISPELAERE, J. HOSTE, J. Radioanal. Chem., 72 (1982) 275.
2. P. SCHUMANN, D. ALBERT, Kernenergie, 2 (1965) 88.
3. T.B. RYVES, Metrologia, 5 (1969) 119.
4. F. DE CORTE, L. MOENS, S. JOVANOVIĆ, A. SIMONITS, A. DE WISPELAERE, J. Radioanal. Nucl. Chem., 102 (1986) 37.
5. F. DE CORTE, S. JOVANOVIĆ, A. SIMONITS, L. MOENS, J. HOSTE, Kernenergie-Kerntechnik, Suppl. to Vol. 44 (1984) 385.
6. F. DE CORTE, A. SIMONITS. Vade Mecum for k_0 -users, DSM Research, Geleen (NL) R29/11492, December, 1994.
7. O.T. HØGDAHL. Neutron absorption in pile neutron activation analysis: determination of copper and gold in silver. Proceed. Symp. Radiochem. Methods of Anal., Salzburg, Oct. 19-23 (1965), IAEA, Vienna, 23-40.
8. F. DE CORTE, K. SORDO-EL HAMMAMI, L. MOENS, A. SIMONITS, A. DE WISPELAERE, J. HOSTE, J. Radioanal. Chem. 62 (1981) 209.
9. F. DE CORTE, A. SIMONITS, J. Radioanal. Nucl. Chem. Articles 133/1 (1989) 43.
10. F. DE CORTE, A. SIMONITS, F. BELLEMANS M.C. FREITAS, S. JOVANOVIĆ, B. SMODIS, G. ERDTMANN, H. PETRI, A. DE WISPELAERE. J. Radioanal. Nucl. Chem. Articles 169 (1993) 125.
11. F. DE CORTE. Ph.D. Thesis, Univ. Gent, 1987.
12. A. SIMONITS, F. DE CORTE, J. HOSTE, J. Radioanal. Chem. 31 (1976) 467.
13. E. HERRERA, A. PERDOMO, C. GARCIA. Spectrum Analyzer. ISCTN, Havana, Cuba, 1995.
14. L.C. PAREDES. Multipurpose Research Reactors. IAEA-STI/PUB/762. (1988). Vienna, p.27.
15. E. HERRERA. Ph.D. Thesis. Univ. Havana, 1995.



CIE

**CENTRO DE INFORMACION
DE LA ENERGIA NUCLEAR**

Calle 20 No. 4113 e/ 18A y 47, Playa

Tel.: 22-7527. Fax: 331188.

E mail: cien @ceniai cu