

CONF-981003--

Int. Conf. Physics of Nuclear Science and Technology

October 5-8, 1998

RADIATION DOSIMETRY AT THE BNL HIGH FLUX BEAM REACTOR*

NE Holden¹, J-P Hu¹, RN Reciniello²

1. Reactor Division,
Brookhaven National Laboratory
2. Safety & Environmental Protection Division,
Brookhaven National Laboratory

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED 

RECEIVED
APR 08 1998
OSTI

MASTER

19980427 079

DTIC QUALITY INSPECTED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Summary

The HFBR is a heavy water, D₂O, cooled and moderated reactor with twenty-eight fuel elements containing a maximum of 9.8 kilograms of ²³⁵U. The core is 53 cm high and 48 cm in diameter and has an active volume of 97 liters. The HFBR, which was designed to operate at forty mega-watts, 40 MW, was upgraded to operate at 60 MW. Since 1991, it has operated at 30 MW. In a normal 30 MW operating cycle the HFBR operates 24 hours a day for thirty days, with a six to fourteen day shutdown period for refueling and maintenance work.

While most reactors attempt to minimize the escape of neutrons from the core, the HFBR's D₂O design allows the thermal neutron flux to peak in the reflector region and maximizes the number of thermal neutrons available to nine horizontal external beams, H-1 to H-9, used for neutron scattering and capture reactions, supporting physics, chemistry and biology experiments. The higher energy neutrons peak within the core region. Materials for irradiation experiments are introduced and irradiated in any of seven vertical thimbles, V-10, V-11 and V-12 in the D₂O reflector, V-13 and V-14 at the core edge, or V-15 and V-16 inside the core center.

All horizontal beam tubes were built tangential to the direction of the emerging core neutrons, except for the H-2 beam tube, which "looks" directly at the core and has been used for neutron cross section measurements utilizing fast neutrons and for the TRISTAN fission product studies. While most beam tubes use ambient temperature neutrons, the H-9 beam tube has a liquid hydrogen moderator system to provide an intense beam of cold neutrons with energies < 5 milli-volts (meV). This Cold Neutron Facility (CNF) provides very low energy neutrons for both inelastic scattering physics and for high resolution small angle scattering biological structure experiments. Inelastic scattering experiments are also performed at H-4M, H-5, H-7 and H-8 beam lines. H-3A is used for protein crystallography and H-3B for intermediate resolution biological small angle scattering. H-1A and H-4S beam lines are used for diffraction of powder samples, while H-6M and H-6S are used for diffraction of single crystal samples.

MODIFICATIONS

In recent years, there have been some beam modifications and new instrumentation introduced at the HFBR. A high resolution neutron powder diffractometer operates with a resolution of 5×10^{-4} at horizontal beam line H-1A. To study scattering from liquid surfaces, a neutron reflection spectrometer was introduced on the CNF beam line at H-9. Within the past few years, a fourth beam line has been added to the CNF line at H-9. This beam is used solely for the testing of new instrumentation design, without interfering with the ongoing experiments at the HFBR.

In the fall of 1996, the existing beam plug at the H-6 beam line

was removed and a new plug, featuring super mirrored surfaces, was installed. This new plug should enable neutron beams to be extracted further from the reactor with minimal scattering loss. Since H-6 has a split neutron beam, this change will allow two to four additional experiments to be performed at this beam port when the HFBR restarts in the future.

The vertical beam thimble, V-13, a fixed port filled with thirty year old samples used for HFBR material surveillance studies has been replaced by a new thimble and charging station at the core edge creating another irradiation facility.

Two in-core thimbles feature a 1/2 thermal to fast ($E_n > 0.1$ MeV) neutron flux ratio. These thimbles are used for radiation damage studies (due to gamma rays and fast neutrons), as well as for fast neutron reaction activation studies; the two core edge thimbles with a 8/1 thermal to fast ratio have a thermal neutron flux density of 5×10^{14} n/cm²/s and have been used for producing ⁶⁴Cu for use as a positron source and for medical radionuclide sources; the three thimbles in the D₂O reflector with thermal to fast ratios varying from 360/1 to 1500/1 are used for production of thermal neutron activated nuclides with little or no accompanying fast neutron activated interfering nuclides and thermal neutron activation analysis. All thimbles, except V-11, are accessed by mechanical means using a four inch long aluminum sample capsule, attached to a quarter inch diameter aluminum tubing that is 37 feet long. The V-11 thimble is part of a hydraulic system which utilizes a plastic or aluminum capsule inside a light water insert within the heavy water cooling system. Aluminum capsules require a fifteen minute waiting period for radiation cooling, while the plastic capsule allows activated samples to be withdrawn with only a thirty to forty second transit time delay. Plastic capsules allow for the production and measurement of short lived activation products.

The HFBR neutron dosimetry effort described here compares measured and calculated energy dependent neutron and gamma ray flux densities and/or dose rates at horizontal beam lines and vertical irradiation thimbles.

IRRADIATION THIMBLE DOSIMETRY

Thermal, resonance and fast neutron activation reaction dosimeters have been exposed in many vertical irradiation thimbles^{1,2} in the reflector region, at the core edge and in the core center over the years. The results of the measurement program have generally been consistent.

To carry out the neutron and photon transport computations, Monte Carlo code³ MCNP-4B2 was used. Both prompt neutron and prompt gamma flux densities were calculated in one run. ENDF/B-VI continuous neutron cross section data were used, including appropriate thermal neutron scattering function $S(\alpha, \beta)$ for D₂O. For a steady state flux estimate in a fresh core, preliminary runs were performed to

predict the critical ($k_{\text{eff}}=1$) control rod bank positions. Relative to the core mid-plane, a main rod tip at +15.735 cm and auxiliary rod tip at -26.9 cm, showed 99% confidence compared to measured rod positions at HFBR startup. A value of $\langle \mu \rangle = 2.61$ neutrons/fission (9×10^{16} n/sec/MW) was used for normalization at 40 MW operating power. The dosimeter samples, which were inserted into vertical thimbles, were simulated by a 0.2 cm thick aluminum shell filled with air in a sphere of 2 cm ID (2.4 cm OD). Energy distributions had been calculated at various axial locations in the thimbles. The statistical uncertainty (standard deviation/mean) is mostly $< 5\%$ for neutrons between 0.023 - 0.55 ev. Neutron and gamma ray fluxes at various axial positions were calculated in all thimbles.

DISCUSSION

There are differences between experimental and calculated values. Calculated values exceed measurements but boundary conditions are different. To simplify calculations, a fresh core with twenty-eight new fuel elements was assumed. Normally, samples are irradiated in an equilibrium core, where only one set of seven fuel elements is new. The other twenty-one elements have been fissioning for up to three thirty day fuel cycles. The control rod tip was 15.735 cm above the core mid-plane for the calculations, while measurements were performed in an equilibrium core, when the control rods were out of the reactor. The active neutron source volume ratios in these two cases is 0.80. For calculated values, quoted uncertainty is strictly statistical based on the number of histories with no systematic error estimated. Calculations with boundary conditions closer to the actual measurement conditions will be performed.

BEAM LINE DOSIMETRY

Various thermal, resonance and fast neutron reaction foils were irradiated at a number of horizontal beam lines^{4,5}. Results indicate a thermal neutron flux density at the sampling position on the order of 10^7 n/cm²/sec compared to 10^{15} n/cm²/sec at the beam tips and with cadmium ratios between 10 and 100. No calculational results are available because of the seven to eight orders of magnitude reduction in the flux density compared to those in the vertical thimbles. Beam line flux densities will require much larger numbers of neutron histories for the Monte Carlo results to have any statistical significance.

At the H-8 beam line, neutron dose rates were measured using a large volume BF₃ detector and found to be 2.4 rem/h. This unshielded dose rate was measured at a distance of several cm from the beam aperture at a neutron energy of 41 milli-ev (meV). Gamma dose rate measurements were also taken with a 0.6 cm³ ion chamber (active volume) to be 22 R/h. Plexiglass shields (1/16" thick) were placed between the beam aperture and the chamber. The gamma dose rate was 14.1 R/h with one shield and was reduced to 0.5 R/h with ten thicknesses. This indicates the gamma dose rate is caused by low energy (< 100 keV) gamma-rays. A subsequent measurement was

conducted using a NaI detector, which confirmed a strong absorption peak in the region 10 to 25 keV.

CONCLUSION

Further work on neutron and gamma-ray dosimetry for the various horizontal beam lines and vertical thimbles are planned, when the HFBR restarts operation in the future. At present, the measured values for neutron flux densities for various vertical thimbles agree with the neutron flux data which has been supplied to HFBR users in the past.

REFERENCES

1. E.Weinstock, private communication, "Flux in V-11 Facility of HFBR", (1968).
2. L.R.Greenwood, R.T.Ratner, private communication, "Neutron Dosimetry and Radiation Damage Calculations for HFBR", (1997).
3. MCNP-4B2 "Monte Carlo N-Particle Transport Code System (CCC-660)", contributed by Los Alamos National Laboratory, January 29, 1997, distributed by the Oak Ridge Radiation Safety Information Computational Center.
4. E.Weinstock, private communication, "Beam Quality Measurements on HFBR with 2" x 2" Collimator" and "Beam Quality Measurements on HFBR with 3', 10', and 30' Collimators" (1966).
5. N.E.Holden, J-P.Hu, L.R.Greenwood, K.Farrell, R.N.Reciniello, S.Sengupta,, "Updated Flux Information for Neutron Scattering and Irradiation Facilities at the BNL High Flux Beam Reactor", Int. Conf. Nucl. Data for Science and Technology, Trieste, Italy, May 19-24, 1997.

*This work was supported in part by the US Department of Energy under contract DE-AC02-76CH00016.

M98004445



Report Number (14) BNL -- 65243
CONF - 981003 --

Publ. Date (11) 199802
Sponsor Code (18) DOE/ER , XF
UC Category (19) UC-413 , DOE/ER

DOE