

PROTECTED-Proprietary
DUPIC Project

KAERI/TR-2511/2003

**REGIONAL OVERPOWER PROTECTION SYSTEM
ANALYSIS FOR A DUPIC FUEL CANDU CORE**

KAERI

2003. 6.

KOREA ATOMIC ENERGY RESEARCH INSTITUTE

제 출 문

한국원자력연구소장 귀하

본 보고서를 2003년도 "건식재가공핵연료 노심특성평가 기술개발"과제의 기술보고서로 제출합니다.

제목 : Regional Overpower Protection System Analysis for a DUPIC Fuel CANDU Core

2003. 6. .

과제명 : 건식재가공핵연료 노심특성평가 기술개발

주저자 : 정창준

공저자 : 최항복

박지원

REGIONAL OVERPOWER PROTECTION SYSTEM ANALYSIS FOR A DUPIC FUEL CANDU CORE

ABSTRACT

The regional overpower protection (ROP) system was assessed a CANDU 6 reactor with the DUPIC fuel, including the validation of the WIMS/RFSP/ROVER-F code system used for the estimation of ROP trip setpoint. The validation calculation has shown that it is valid to use the WIMS/RFSP/ROVER-F code system for ROP system analysis of the CANDU 6 core. For the DUPIC core, the ROP trip setpoint was estimated to be 125.7%, which is almost the same as that of the standard natural uranium core. This study has shown that the DUPIC fuel does not hurt the current ROP trip setpoint designed for the natural uranium CANDU 6 reactor.



TABLE OF CONTENTS

SECTION	PAGE
ABSTRACT	2
1. INTRODUCTION	7
2. ROPT ANALYSIS METHODOLOGY	15
2.1 Protection Equation	15
2.1.1 Basic Equation	15
2.1.2 Modification and Corrections	16
2.1.3 Final Form of Protection Equation	21
2.2 Probabilistic Assessment Methodology	22
2.3 ROP Design Data	22
2.3.1 Flux Shapes	22
2.3.2 Critical Channel Power	24
2.3.3 Probabilistic Assessment	24
3. VALIDATION CALCULATIONS FOR WIMS/RFSP/ROVER-F SYSTEM	28
3.1 Calculation Procedure	28
3.1.1 RFSP Physics Calculations	28
3.1.2 CCP Calculations	28
3.1.3 Ripple Data	28
3.2 Calculation Results and Summary	29
4. ROPT SETPOINT ASSESSMENT FOR DUPIC CORE	32
4.1 Calculation Procedure	32
4.2 ROVER-F Input Data Files	32
4.2.1 CASE Data	32

4.2.2 CCP Data	32
4.2.3 CP Data	32
4.2.4 CPPF Data	33
4.2.5 DET1 Data	33
4.2.6 DET2 Data	33
4.2.7 ERR Data	33
4.2.8 MAP Data	34
4.2.9 ORIF Data	34
4.2.10 RIPPLE Data	34
4.2.11 SIZE Data	34
4.2.12 TASK Data	34
4.3 ROVER-F Calculations	35
4.3.1 Trip Setpoint	35
4.3.2 Single Detector Failure	35
4.3.3 Reform Calculation	35
5. SUMMARY AND FUTURE WORKS	38
REFERENCES	39
APPENDIX	40


TABLES

PAGE

Table 2.1 Estimated ROP Errors and Uncertainties for Wolsong-1	26
Table 3.1 Case Set for Natural Uranium Core Analysis	30
Table 3.2 Uncertainty Data for Natural Uranium Core Analysis	31
Table 4.1 Uncertainty Data for DUPIC Core Analysis	36
Table 4.2 Trip Setpoint for Single Detector Failure	37



FIGURES	PAGE
Fig. 1.1 ROP Trip Logic for Shutdown System No. 1	8
Fig. 1.2 ROP Trip Logic for Shutdown System No. 2	9
Fig. 1.3(a) SDS1 Detector Locations (Assemblies 1 to 9)	10
Fig. 1.3(b) SDS1 Detector Locations (Assemblies 10 to 17)	11
Fig. 1.3(c) SDS1 Detector Locations (Assemblies 18 to 26)	12
Fig. 1.4(a) SDS2 Detector Locations (Assemblies HFD-4 and 8)	13
Fig. 1.4(b) SDS2 Detector Locations (Assemblies HFD-4 and 8)	14
Fig. 2.1 CPPF Region	27



1. INTRODUCTION

In CANDU reactors, the Regional Overpower Protection Trip (ROPT) system protects the reactor against overpowers in the reactor, which would be due to the local power or the reactor power level increases. The design requirements of the ROPT system, which have been established for the natural uranium CANDU 6 reactor, are summarized in Ref. 1. In the CANDU core there are two ROPT systems - one for each of the two fast-acting shutdown systems (SDS's). Each ROPT system consists of a number of fast-responding self-powered flux detectors, suitably distributed throughout the core within vertical or horizontal assemblies. The SDS1 ROPT detectors are located in some of the 26 vertical assemblies, which are shared with other flux detectors used for reactivity control and flux mapping. The SDS2 ROPT detectors are located in seven horizontal assemblies. Each ROPT detector has a pre-set trip setpoint and each SDS is connected to three logic channels. The reactor trip occurs when two channels out of three are tripped (see Figs. 1.1 and 1.2). Figures 1.3 and 1.4 show the SDS1 and SDS2 detector locations, respectively.

The ROPT system has detectors, which are distributed throughout the core to ensure the coverage of the local flux and power peaks that could arise due to normal maneuvering or abnormal combinations of reactivity devices. The design of the ROPT system is essentially a choice of a set of detector locations that could provide the overpower protection for a pre-defined "design-basis" set of flux shapes (device configurations), while maximizing operating margins of detectors for more common operating conditions.

The design and operation parameters of the ROPT systems are subject to errors and uncertainties, which are detector random, channel random, common random uncertainties and bias. To ensure the safe operation of the ROPT system, appropriate allowance must be made for the expected errors. This is done by a probabilistic assessment of the ROPT system, in which the setpoint level is determined to ensure, despite the error, a 98% probability of tripping prior to the critical channel power being exceeded for any of the design-basis flux shapes. This trip probability assessment is done on a 2-out-of-2 basis - assuming (for each SDS) the logic that the channel most likely to trip is unavailable.

This report describes the probabilistic assessment of the ROPT system for the CANDU 6 reactor with the DUPIC fuel. In Sec. 2, the ROP analysis methodology is described. The computer code system used for the DUPIC core analysis is validated in Sec. 3, and the ROP analysis results of the DUPIC core are given in Sec. 4. Finally, summary and future works are presented in Sec. 5.




Fig. 1.1 ROP Trip Logic for Shutdown System No. 1




Fig. 1.2 ROP Trip Logic for Shutdown System No. 2




Fig. 1.3(a) SDS1 Detector Locations (Assemblies 1 to 9)




Fig. 1.3(b) SDS1 Detector Locations (Assemblies 10 to 17)




Fig. 1.3(c) SDS1 Detector Locations (Assemblies 18 to 26)




Fig. 1.4(a) SDS2 Detector Locations (Assemblies HFD-4 and 8)




Fig. 1.4(b) SDS2 Detector Locations (Assemblies HFD-5 and 9)

2. ROPT ANALYSIS METHODOLOGY

The detailed analysis methods, assumptions and data intended to be used in the ROPT assessment are described in Ref. 2. In this section, the basic analysis methods are summarized.

2.1 Protection Equation

2.1.1 Basic Equation

- a) In design and operation of the ROPT systems, the flux and power changes that occur in the reactor are separated into two components:
- ripple, which is the variation in the core power distribution due to fueling and burnup; and
 - flux-shapes, which are the variation of flux and power from the nominal due to a perturbation in the device configuration (including zone controller water movements) or xenon changes.
- b) The basic ROPT protection requirement is: for any flux-shape k and ripple q , the reactor shall be tripped (on all three safety channels) before any coolant channel reaches its critical channel power. That is, the ROPT systems shall have detector locations, channelizations and trip setpoints (TSP) such that for every design-basis flux-shape k , there is at least one detector j_p (the "protecting" detector) in each safety channel i , which can be written as,

$$\text{TSP}(j_p) \leq \Phi^T(j_p, k, q) \quad (1)$$

$$\text{where } \Phi^T(j, k, q) = D_o(j) \frac{\phi(j, k, q)}{\phi_o(j, q)} * r_{\text{CPRL}}(k, q) \quad (2)$$

- and
- TSP is the trip setpoint for detector j ,
 - D_o is the detector's initial calibration at 100% full power (FP)
 - Φ^T is the required trip setpoint for detector j_p if it is to protect flux-shape k with ripple q ,
 - ϕ is the flux at detector j for flux shape k and ripple q ,
 - ϕ_o is the nominal flux at detector j at 100% power FP ripple q ,

r_{CPRL} is the minimum critical power ratio (CPR) for flux shape k and ripple q , that is the minimum value (over the 380 fuel channels) of the ratio of the channel critical channel power (CCP) to the actual channel power (CP).

$$\text{That is, } r_{\text{CPRL}}(k,q) = \min_m \left[\frac{\text{CCP}(m,k)}{\text{CP}(m,k,q)} \right], \quad (3)$$

where, m is the channel index.

2.1.2 Modification and Corrections

In practice, a number of modifications are made to these basic equations for took consider the calculation uncertainties and operating conditions.

a) Allowance for uncertainties

The final level of setpoints for the ROPT designs are determined by a trip probability calculation for each of the design-basis flux-shapes. In this calculation, the TSP's are in effect reduced to provide an implicit margin for errors and uncertainties (EAF), for each case, sufficient to ensure 98% 2-out-of-2 trip probability on all design-basis cases.

b) Superposition

A basic ROPT assumption is that the flux and power changes due to the device configuration are independent of the flux and power ripple: that is

$$\frac{\phi(j,k,q')}{\phi_o(j,q')} = \frac{\phi(j,k,q'')}{\phi_o(j,q'')} = \frac{\phi(j,k,TA)}{\phi_o(j,TA)} = \frac{\phi'(j,k)}{\phi_o'(j)} \quad (4a)$$

$$\frac{\text{CP}(m,k,q')}{\text{CP}_o(m,q')} = \frac{\text{CP}(m,k,q'')}{\text{CP}_o(m,q'')} = \frac{\text{CP}(m,k,TA)}{\text{CP}_o(m,TA)} = \frac{\text{CP}'(m,k)}{\text{CP}_o'(m)} \quad (4b)$$

where q' and q'' are particular ripples or times, TA is the time-average simulations used for the ROPT design, and ϕ' and CP' are the general form of the flux and channel power, respectively, which are independent of q .

c) Reference powers

The CP terms in Eq. (3) can conveniently be separated into terms which measure the change

due to the ripple and flux-shape:

$$CP(m, k, q) = CP_o(m, q) * \frac{CP'(m, k)}{CP_o(m)} \quad (\text{from 4b})$$

$$= CP_{ref}(m) * \frac{CP_o(m, q)}{CP_{ref}(m)} * \frac{CP'(m, k)}{CP'_o(m)} \quad (4c)$$

due to due to device
ripple perturbation

where CP_{ref} is the reference power distribution. It could be the time-average nominal power, or any arbitrary set of channel powers. The process that changes the initial time-average nominal power (CP_{o-TA}) to CP_{ref} is called "Reforming".

d) Nominal CPR Limit (Reformed Nominal)

The r_{CPR_L} (in Eq. (2)) is the limiting CPR for the flux-shape in a specific rippled power distribution q . It is also possible to define a limiting CPR for that case in the time-average CP distribution (as reformed to the CP_{ref}).

$$CPR_L(k) \equiv \text{Min}_m \left[\frac{CCP(m, k)}{CP'(m, k) * \frac{CP_{ref}(m)}{CP_o(m)}} \right] \quad (5)$$

This is the more usual definition of the limiting CPR at the design stage, when analyses are done with time-average values. Note that the second quantity in the denominator of Eq. (5) is the "Reform" factor for channel m .

e) Calibration and CPPF

i) If the ROPT detectors are calibrated to each ripple, i.e., to read 100% FP, then the calibration automatically divides out the rippled nominal flux distribution $\phi_o(j, q)$. In response to a device perturbation k , the detectors will then read $D_o[\phi'(j, k)/\phi_o(j)]$.

ii) Operational

This can be taken one step further by allowing for the maximum channel power ripple (CP_o/CP_{ref} in Eq. (4c)) in the detector calibrations. That is, for any ripple q ,

the ROPT detectors are all calibrated to a ripple factor called the Channel Power Peaking Factor (CPPF) - i.e., after calibration, all detectors will read the CPPF (at 100% FP) ($D_o = \text{CPPF}$ on all detectors). The CPPF is defined as the maximum ratio of CP_o to CP_{ref} over a specified potentially-limiting central-core region ('CPPF region').

$$\text{CPPF}(q) = \text{Max}_m \left[\frac{CP_o(m, q)}{CP_{ref}(m)} \right]_{\text{CPPF Region}} \quad (6)$$

The CPPF region is shown in Fig. 2.1. Limiting the CPPF to this central-region is necessary so that high ripples in peripheral channels will not unnecessarily penalize operating ROPT margins. The CPR's are much higher for the peripheral channels.

iii) Ripple Conservatism

Combining Eqs. (4c) and (6), the r_{CPRL} in equation Eq. (3) can be replaced as follows:

$$r_{\text{CPRL}}(k, q) = \text{Min}_m \left[\frac{\text{CCP}(m, k)}{CP(m, k, q)} \right] = \text{Min}_m \left[\frac{\text{CCP}(m, k)}{CP_{ref}(m) * \frac{CP_o(m, q)}{CP_{ref}(m)} * \frac{CP'(mk)}{CP'_o(m)}} \right] \quad (7a)$$

$$= \text{Min}_m \left[\frac{\text{CCP}(m, k)}{CP'(m, k) * \frac{CP_{ref}(m)}{CP'_o(m)}} / \frac{CP_o(m, q)}{CP_{ref}(m)} \right] \quad (7b)$$

This quantity looks like the CPR_L (Eq. (5)) divided by CPPF (Eq. (6)). However, the effect of the $\text{Min}(m)$ must first be considered. In general, the channel m that is limiting in equation (7a) (i.e., in the rippled perturbed flux-shape) will not be the same as the channels that are limiting in Eqs. (5) and (6) (limiting CPR in time-average and limiting ripple, respectively). The effect of this difference in limiting channel location is non-trivial; the use of the limiting ripple (CPPF) combined with the limiting time-average CPR results in a significant conservatism relative to the limiting CPR, which is actually applied to the flux-shape/ripple combination. This conservatism is typically 4 to 5%. Hence, a quantity called the "ripple conservatism" (R_c) is defined, which accounts for the conservatism of the critical power ratio.

$$R_c(k, q) \equiv \frac{\text{CPPF}(q) * r_{\text{CPRL}}(k, q)}{CPR_L(k)} \quad (8)$$

In the ROPT probabilistic assessment the ripple conservation is assessed using representative set of ripples. The Eq. (8) allows Eq. (7b) to be taken out of the brackets, giving:

$$r_{\text{CPRL}}(k, q) = \text{Min}_m \left[\frac{\text{CCP}(m, k)}{\text{CP}(m, k, q)} \right] = \frac{R_c(k, q) \cdot \text{CPR}_L(k)}{\text{CPPF}(q)} \quad (7c)$$

iv) In practice, the ROPT detectors may be calibrated at powers other than 100% FP, e.g., at a rated power (RP_c). The detectors are then calibrated to each reading D_c at that power level, where $D_c = \text{CPPF} * RP_c$. The detectors will then read the CPPF when the reactor power returns to 100% (assuming the linearity of the detector signal with reactor power). D_c may also incorporate other operating corrections.

f) Operating Corrections (CCPs)

The initially calculated CCPs are subject to several potential sources of variations. These are taken into account as follows:

- i) CCP boundary-conditions correction $F_{\text{TP}}(k)$: The CCPs are calculated for reference thermo-hydraulic boundary conditions ($\Delta P_{\text{HH}}, T_{\text{RIH}}$ and P_{ROH}) that are based on 100% FP values. However, for most flux-shapes, the reactor does not trip at 100% and the header conditions will differ. This correction factor accounts for the CCP change due to changes in ΔP_{HH} and T_{RIH} at the reactor power at which a case would (on average) reach the limiting CCP (reduced for errors). Since setpoints are not initially known, it is both convenient and conservative to evaluate this at the reactor power corresponding to the limiting CPR for that case, allowing for the average CPPF and error allowance EAF (i.e., critical power, not trip power). An uncertainty term accounts for the effect of variations in this critical power for the case.
- ii) Changes in $\Delta P_{\text{HH}}, P_{\text{ROH}}$ and T_{PIH} with time: The primary heat transport (PHT) boundary conditions ($\Delta P_{\text{HH}}, P_{\text{ROH}}$ and T_{PIH}) are checked at regular intervals. The CCP effect of any changes are accounted for simply as an operational correction to the detector calibration D_c .
- iii) CCP correction for each channel

Several types of CCP corrections (if and when present) will vary from channel to channel. These include:

- Correction for NUCIRC [Ref. 3] systematic flow errors. These may vary with

- feeder geometry, orificing, location on headers, etc.
- Operating corrections for changes in fuel type, or fuel bundles with excess mass [4]
 - CCP corrections for pressure tube diametrical creep (if variable radially)

The channel-variable CCP corrections, available when the ROPT design analysis is done are incorporated directly into the analysis as correction factor $F_{CH}(m)$. However, some channel-variable CCP corrections will only arise subsequently, while the reactor is operating. These are then accounted for as a correction to the CP_{ref} 's in the CPPF calculation. That is, the definition of the CPPF is revised as follows:

$$CPPF(q) = \text{Max}_m \left[\frac{CP_o(m, q)}{CP_{ref}(m) * F_{CR}(m)} \right], \quad (9)$$

where $F_{CR}(m)$ is the correction factor for those channel-related CCP corrections not included in $F_{CH}(m)$ (or F_{TP} or D_C).

g) Flux-shape Correction for Coolant Boiling

In the flux-shape simulations, the effect of coolant boiling on the flux and power distribution was ignored in the core modelling. At the powers of the cases usual operating cases, the effect of boiling is small, and this simplifying assumption causes little error. However, at the powers at which the ROPT cases are likely to trip (e.g., 110 to 115% FP, depending on the case and ripple), there is more boiling, and it begins to have a measurable effect on the detector flux readings. This was analyzed in Ref. 3, for the nominal case trip at 120% FP (an upper limit to the likely range of trip powers). The resulting flux changes due to boiling were found to be generally negative for ROP setpoint (except at the ends of the reactor), strongly correlated with a detector's axial location within core, but fairly constant at a given axial location (i.e., along a given detector assembly a_j).

Hence, the flux changes due to coolant boiling at trip power are implemented as an assembly-related correction factor, $F_B(a_j)$. This correction is assumed to be independent of the flux-shape based on the following logic:

- The limiting (central-core) CCPs are fairly similar for all flux-shapes (the maximum difference is 5-6%); hence, at the trip power, the limiting channels for any flux-shape will be at a trip power, and have a degree of boiling, comparable to the nominal case analyzed. Other channels may have less, but the limiting channels will have a similar

degree of boiling.

- Then, conservatively, it is assumed that the protecting detectors for this flux-shape are located in the region of the peak-power channels, and will therefore see a similar degree of boiling-related flux change.

h) Dynamic Compensation

The signal from the ROPT detectors is subject to various dynamic delays, and is compensated electronically to ensure that the detector signal seen equals or exceeds the fuel power during any transient. The compensated signal ratio can be designated C(t).

i) Setpoint Handswitch Positions

To ensure that the ROPT coverage is maintained during various abnormal operating conditions, the detectors have three different levels of setpoints which are selected by hand switches on the SDS1 and SDS2 control panels:

- Hand switch position No. 1 (HSP-1) = setpoints for normal operations
- HSP-2: setpoints for abnormal flux-shapes (device configurations that are either unanalyzed, or have been found not to be covered by the HSP-1 setpoints)
- HSP-3: setpoints for symmetric one HTS pump per coolant loop operation.

2.1.3 Final Form of Protection Equation

- a) Taking into account all these modifications and corrections, Eqs. (1) and (2) may thus be re-written for the protecting detectors j_p :

$$\begin{aligned}
 \text{TSP}(j_p) \leq D_o & \cdot \frac{\left[\frac{\phi(j, k)}{\phi_o(j)} \right]_{\text{prot}}}{\left[\frac{\text{CP}(m, k)}{\text{CP}_o(m)} \right]_{\text{Lim}}} \cdot \left[\frac{\text{CCP}(m, k)}{\text{CP}_{\text{ref}}(m)} \right]_{\text{Lim}} \cdot \frac{R_c(k, q) \cdot F_B(a_j) \cdot F_{\text{CH}}(m) \cdot F_{\text{TP}}(k)}{\text{CPPF}(q)} \\
 & \cdot \frac{C(t)}{\text{EAF}(k)}
 \end{aligned}
 \tag{10}$$

where "prot" identifies the detector(s) relied on to protect case k, and "Lim" is the CPR limiting channel. For conventional, the primes on ϕ and CP are dropped. Note that CPPF is determined using Eqs. (6) or (9), as appropriate. Note also that if $D_o = \text{CPPF}$ (i.e., detectors calibrated to the CPPF), TSP becomes constant and independent of the actual ripple.

b) A "protecting" detector is one that satisfies the above equation. For each flux-shape, there must be at least one "protecting" detector in each trip channel (usually the one with the largest ϕ/ϕ_0). Taking into account the randomizing effects of detector-to-detector errors in calibration, simulation, setpoints, etc., the "protecting" detectors for a flux-shape are those likely to trip first in each trip channel. A "Limiting" channel is one with the minimum ratio of CCP/CP for a given flux-shape k and ripple q , which may also vary due to channel-related errors.

2.2 Probabilistic Assessment Methodology

The ROP coverage equation is so structured that independent aspects of the ROP coverage (flux shapes, CCPs, ripples) are each separately represented by a different error and uncertainty terms. The purpose of the probabilistic assessment is to evaluate the adequacy of a given ROP error allowance, or conversely to determine the error allowance needed to meet a certain confidence limit, given specified ROP system and the expected errors and uncertainties.

The trip probability for a particular flux-shape is an average over various rippled power distributions and for the estimated errors used in the assessment. The probabilistic assessment may include a determination of a set of CP_{ref} 's that maximize the level of setpoints (probabilistic "Reform"). Once the level of setpoints has been determined for the design-basis cases, trip probabilities may also be determined for the non-design-basis cases. The detailed probabilistic assessment methodology is described in Refs. 5, 6 and 7.

2.3 ROP Design Data

2.3.1 Flux Shapes

2.3.1.1 Design-Basis Cases

The first step in the ROPT design is the choice of design basis cases (flux-shapes). The choice of cases for the design-basis set determines the coverage capabilities and characteristics of the ROPT systems during normal operations (i.e., with HSP-1 setpoints).

a) Design Goals

The design goals for the ROPT system are:

- i) that the ROPT covers all normal operating device configurations, reactor conditions, and normal device configurations with the HSP-1 setpoints, without regard to:
 - presence or absence of spatial control
 - variations in average zone controller levels
 - variations in xenon, concentration, whether local or global; and
- ii) that the ROPT coverage be robust, that is, the design shall have a high probability of covering a non-design-basis device configuration (with HSP-1 setpoints).

b) Design-set Required

To achieve the above design goals, the design-basis cases should include the following categories of cases:

- i) a complete set of cases with a single reactivity device withdrawn or inserted (adjusters, MCAs or zone controllers)
- ii) a set of cases with partial insertions or withdrawals of devices (i.e., devices half-in or out, zone controllers drained from 50% or 20% full)
- iii) all cases done with spatial control
- iv) a full range of adjuster transients (shim, short startup, startup after poison-out, stepback) to ensure the range of xenon distribution is covered
- v) for all other perturbations, instantaneous simulations (no xenon transients)
- vi) a full set of harmonic flux tilts.

The design-basis (D/B) case-set for the CANDU 6 ROPT systems arising from these requirements is summarized in Table A.1 of Appendix. It totals 232 cases.

2.3.1.2 Flux-shape Processing

- a) The thermal neutron fluxes calculated by RFSP[10] for each flux-shape must be processed to obtain the detector responses at each ROPT detector location. This processing includes:
 - interpolation to obtain fluxes along assembly axes
 - summation along the detector and lead-cables
 - corrections for core-model differences
 - division by the nominal detector flux to get (ϕ/ϕ_o) .

b) Correction for Boiling

Flux-shape corrections are performed for the coolant boiling as a function of assembly number. This correction is implemented in the probabilistic assessment. [4]

2.3.2 Critical Channel Power (CCP)

2.3.2.1 Design Criterion

The design criterion for the ROPT system is the prevention of fuel dryout – specifically, the onset of intermittent dryout (OID). For a given flux-shape, this criterion translates into a set of CCPs (critical channel powers) for each channel – the channel power at which dryout (OID) is reached somewhere along the channel.

2.3.2.2 Design Calculation

The CCPs are calculated for all 232 design basis cases. The CCPs are calculated using the critical quality and boiling length (X_c-L_b) CHF correlation, which is based on Chalk River National Laboratory (CRNL) tests for 37-element simulated fuel bundles. [8] The Wolsong-1 CCPs are corrected to the following HTS reference header boundary conditions:

T_{RH} :	266°C
ΔP_{HH} :	1342 kPa
P_{ROH} :	9.998 MPa(g)

2.3.3 Probabilistic Assessment

2.3.3.1 Applicable Errors and Uncertainties

The random and systematic errors used in the Wolsong-1 ROPT assessment are listed in Table 2.1. The detailed uncertainties are described in Ref. 4. Table 2.1 gives the ROPT errors for Wolsong-1, with the error totals in each category are:

Detector-random uncertainty:	σ_{d-r}	= ±2.60%
Channel-random uncertainty:	σ_{ch-r}	= ±1.49%
Common-random uncertainty:	σ_{com-r}	= ±4.18%
Overall bias (systematic errors):	$\bar{\varepsilon}$	= ±0.14%

2.3.3.2 Ripples

The probabilistic assessment uses a set of rippled power distributions, representative of the ripples expected in the operating reactor, to estimate the ripple conservatism found for each flux-shape and ripple. The ripples can be obtained from actual plant operating data or

refueling simulation calculation.




Table 2.1 Estimated ROP Errors and Uncertainties for Wolsong-1

Source of Errors	Estimated Magnitude (%)			
	Detector Random	Channel Random	Common Random	Bias Error
<u>1. Detector-Related Errors</u>				
Trip Setpoint	±0.18%		±0.14%	~0
Buffer Amplifier	±0.10		±0.10	
Dynamic Compensation	±0.60			
<u>2. Flux-Shape Errors</u>				
Simulation Error	±1.88	±1.06	±1.07	+0.14
Change due to Boiling				-0.20
Lead-Cable Contributions	±0.20		±0.10	-0.20
Off-Nominal Core			±0.80	
<u>3. CCP Errors</u>				
CHF Correlation Errors			±1.70	0.66
Incomplete Instrumentation				-0.19
NUCIRC Pressure Loss Term		±0.89	±0.83	-2.20
Uncert. In HTS Bndy Conds			±2.32	
Chge in Ref. HTS Bndy Conds				4.18
HTS variations			±0.15	
Channel Age Correction		±0.15		
CCP Change		±0.10		
Normal Operating Flux Tilt				-0.20
Different Fuel Type		±0.44		
Allowance for PT Creep				-1.00
<u>4. Calibration Errors</u>				
CP/PPF Calculation			±1.50	0.20
Thermal Power Calculation			±1.70	
CPPF Drift Error			±0.80	
Calibration Drift Error	±1.60			
TOTALS	±2.55%	±1.46%	±4.07%	+0.19%




Fig. 2.1 CPPF Region

3. VALIDATION CALCULATION FOR WIMS/RFSP/ROVER-F SYSTEM

In the ROP analysis of the DUPIC core, a lattice code WIMS-AECL [Ref. 9] is used instead of POWDERPUFS-V (PPV) [Ref. 10], which is used for the standard 37-element natural uranium fuel core. This section describes the validation results of the WIMS/RFSP [Ref. 11]/ROVER-F [Ref. 12] system for ROP analysis by comparing the results with the PPV/RFSP/ROVER-F calculation. The validation calculations are performed for the standard 37-element natural uranium core. Probabilistic assessment of ROPT system for the CANDU reactor with DUPIC fuel has been performed. In this study, 26 limiting cases were chosen based on the results of the Ref. 13. The cross-sections were produced by WIMS-AECL and PPV separately, and the flux shape and detector response were generated by RFSP, critical channel powers (CCPs) were calculated by NUCIRC (Version 1.505), and finally ROVER-F was used to estimate the ROP trip setpoint.

3.1. Calculation Procedure

3.1.1 RFSP Physics Calculations

The RFSP physics calculations are performed to obtain flux shapes and channel powers. The bundle powers are used for CCP calculations. The physics calculations are performed for 26 limiting design basis cases [13], which are shown in Table 3.1. The thermal neutron fluxes calculated for each case are processed to obtain the detector responses at each detector location. This process is performed by INTREP module of the RFSP code.

3.1.2 CCP Calculations

The CCPs are calculated for all flux shape cases. For both fuel types, the same operating conditions were used. The detailed methodology and calculation procedure are described in Ref. 14.

3.1.3 RIPPLE Data

The ripple data presents changes of the instantaneous channel powers for the operating reactor, based on operating plant data. For this study, the ripple data of Wolsong-1 reactor, based on the operating history, were used. The ripple data consist of 150 sets obtained from 1997 to 1999. This data has an average CPPF of 1.0706.

3.2 Calculation Results and Summary

Table 3.2 presents the uncertainty data used for the probabilistic assessment. The calculation results are shown in Table A.2 and Table A.3 of Appendix for each code system. The trip setpoint based on WIMS-AECL is 122.90%, and the setpoint based on PPV is 121.77%. The difference is <1%, which is small enough to accept that the Therefore, it can be concluded that the WIMS/RFSP/ROVER-F system is consistent with the PPV/RFSP/ROVER-F system.




Table 3.1 Case Set for Natural Uranium Core Analysis

Case	Description
1	SSSC50 STEADY-STATE WITH S.C.
37	D14C50 ZONE DRAIN 14 FROM 50%
39	D02C80 ZONE DRAIN 02 FROM 80%
42	D05C80 ZONE DRAIN 05 FROM 80%
44	D07C80 ZONE DRAIN 07 FROM 80%
46	D09C80 ZONE DRAIN 09 FROM 80%
49	D12C80 ZONE DRAIN 12 FROM 80%
51	D14C80 ZONE DRAIN 14 FROM 80%
53	D02N50 ZONE DRAIN 02 FROM 50%
58	D07N50 ZONE DRAIN 07 FROM 50%
60	D09N50 ZONE DRAIN 09 FROM 50%
65	D14N50 ZONE DRAIN 14 FROM 50%
114	MCAN2H MCA 1ST FI & 2ND HI
122	ZTSFSE 1ST AZIMUTHAL SIDE/SIDE
123	ZTSESF 1ST AZIMUTHAL SIDE/SIDE
130	ZT2A01 2ND AZIMUTHAL 135,315 HI
131	T2A02 2ND AZIMUTHAL 045,225 HI
152	SSSD03 BANK 7 FULL-IN/NO TIMESTEP
171	SA4403 BANK 7 FULL-IN
173	SA4405 BANK 6 FULL-IN
174	SA4406 BANK 6 FULL-IN/Xe @ 4.3 MIN
177	SA4409 BANK 4 FULL-IN
178	SA4410 BANK 4 FULL-IN/Xe @ 3.9 MIN
195	SBCK05 BANK 2 OUT/Xe @ 18.3 MIN
196	SBCK06 BANK 3 OUT
197	SBCK07 BANK 3 OUT/Xe @ 28.5 MIN
222	ABHO01 STARTUP BANK 7 HALF-IN

Table 3.2 Uncertainty Data for Natural Uranium Core Analysis

Uncertainty	Value (%)
Detector Random	2.60
Channel Random	1.49
Common Random	4.18
Bias	+0.14



4. ROPT SETPOINT ASSESSMENT FOR DUPIC CORE

This section describes the probabilistic assessment of ROPT system for the CANDU reactor with DUPIC fuel. For the ROPT assessment, 232 design base cases were considered with some exceptional cases of harmonic tilts and restart after long shutdown. The cross-sections of the DUPIC fuel were produced by WIMS-AECL (Version 2.3), and the rest of the procedure to estimate the ROP trip setpoint of the DUPIC core is the same as that of the natural uranium core.

4.1 Calculation Procedure

The physics calculations were performed for 232 design basis cases with exception of some cases; 4 cases of startup after long shutdown and 10 cases of harmonic top-to-bottom and side-to-side tilt. The ROP detector responses at each detector location were obtained from the thermal neutron fluxes calculated for each flux shape, which is performed by *INTREP module in the RFSP code. The ripples used in this assessment were obtained from 600 FPD refueling simulation. A total of 121 ripples were generated for every 5 FPDs.

4.2 ROVER-F Input Data Files

In this study, the input files of the ROVER-F are prepared based on Ref. 13. It includes an overview of the data files used for components of the ROP analysis.,

4.2.1 CASE Data

The design basis cases are the standard ROP case data set consisting of 232 cases. The case data file lists ROP cases sequentially, with identifiers, names, and pointers to the CCP, CP and DET1 files for each of the 232 cases. In this study, 4 cases of startup after long shutdown and 10 cases of harmonic tilts are not considered, but will be performed later.

4.2.2 CCP Data

The CCP data files are generated for the DUPIC core using NUCIRC code. This data set consists of 232 ROP cases for 380 channels. The CCPs are stored in Mega Watt (MW).

4.2.3 CP Data

The CP data files consists of 232 ROP cases for 380 channels. This file contains CP values

calculated by RFSP code for the DUPIC core. The CP data are stored in MW too.

4.2.4 CPPF Data

The CPPF consists of the maximum ripple within the CPPF region for each ripple case. A CPPF region is chosen to exclude the outer channels that have representatively high ripples. The data file contains information on which channels comprise the CPPF region.

4.2.5 DET1 Data

The detector layout specifies the arrangement of the ROP detectors, both in logic channels and shutdown systems. It identifies the setpoints, boiling point correction factors, and response data for each detector, as well as detector failure and compensation. This data provides linkage to the logic system and the detector response data in the DET2 data file.

To re-calculate the Ref. 13 setpoint for Wolsong-1, a change must be made to the detector pointers. The Canadian CANDU plants have swapped the locations of detectors 1H and 1J, which is reflected in the detector response data. Since this has not been implemented in Wolsong-1, the pointers for detectors 1H and 1J must instead be swapped to reflect this difference. Detector 1H is pointed at detector response number 51 for each flux shape, in the set of 58 detector responses. Detector 1J is similarly pointed to response 43. All other detectors remain unchanged. The detector layout is the same as before and four plateaus are used, which is consistent with Ref. 13.

4.2.6 DET2 Data

The DET2 data file contains the ROP detector responses for each of the ROP flux shapes. Thus, data for the 58 ROP detector responses for each of the 232 ROP design basis cases are included.

4.2.7 ERR Data

The ERR data file contains the uncertainties used in the calculation of the ROP setpoint, which are described in detail in Ref. 4. The boundary conditions for the ROVER-F calculation are also set in this file, which are the widths of the bins used to sort the limiting rippled critical power ratios.

For DUPIC core analysis, the channel random uncertainty for fuel types is 0.93% [6], which increases the channel random error from 1.49% to 1.97%. The other uncertainties are same as those of Ref. 13. The boundaries of the calculation were set to 0.7 and 1.2, which are

typically used in ROVER-F analysis. This is a slight change from the original TTR-289 analysis that used 1.1 as an upper boundary; however, this change provides an additional accuracy. The width of the bins remains the same as the standard 0.5%. Table 4.1 shows the uncertainty data used in this study.

4.2.8 MAP Data

The MAP data file contains data on the layout of the channels in the core for the purpose of generating printed maps. In this study, the standard layout file is used.

4.2.9 ORIF Data

The ORIF correction file contains a number of modifications to the CCP values. These modifications pertain to the orifices, the power correction factor, and the NUCIRC version correction factors. Additionally the nominal and reference ROP cases are defined in this file. For DUPIC core analysis, the correction values are the same as described in Ref. 13. The nominal and reference cases are both set to ROP case 001.

4.2.10 RIPPLE Data

The ripple data presents a description of the changes to instantaneous channel power of the operating reactor, based on the operating history of the plant. For DUPIC core analysis, the ripple data were generated from the 600-FPD refueling simulation. A set of 121 ripple cases was chosen from the refueling simulation. The average CPPF of the ripple data is 1.0681.

4.2.11 SIZE Data

The size data file sets the sizes of the data sets to be read, and the number of points used in the analysis. In the TTR-289 analysis, the number of shapes for cases, CPs, CCPs, and detector responses is 926. Only the first 232 cases are used for the DUPIC core calculation. The number of ripples is 121. The number of detectors and detector responses are 58. The number of fuel channels is 380. The number of safety channels and shutdown systems are 6 and 2, which are the standard values. The number of plateaus is 4; however, all plateaus are set to be the same as in Wolsong-1. The number of integration points is 51.

4.2.12 TASK Data

This specifies the calculation to be performed by ROVER-F and the ROP cases that are to be used for that calculation. In TTR-289 analysis, the setpoint is calculated based on ROP cases 1 to 232. The trip confidence calculation is performed for these ROP cases.

4.3 ROVER-F Calculation

Using the input data, described in Sec. 4.2, ROVER-F calculations were performed to assess the ROP system characteristics of the DUPIC core.

4.3.1 Trip Setpoint

The trip setpoint was calculated for DUPIC core. The ROVER-F calculation results of each case are shown in Appendix. The uncertainties used are shown in Table A.4 of Appendix. From this results, the trip setpoint (based on a 98% 2 out of 2 trip probability over 232 design basis cases) of the DUPIC core is 123%, which is almost the same as that of the current ROP setpoint of the natural uranium core (Wolsong-1), 122%. Therefore, it is expected that the loading of the DUPIC fuel in the CANDU-6 reactor does not affect in ROP setpoint.

4.3.2 Single Detector Failure

The trip setpoint was evaluated for the case of a single detector failure, which may change the trip setpoint. Table 4.2 shows the trip setpoint change for single detector failure case. It can be seen that the trip setpoint does not change in case of SDS1 detector failure, but the maximum decrease in the trip setpoint is ~11% in case of some SDS2 detector failures.

4.3.3 Reform Calculation

REFORM is a process that attempts to improve ROP margin by changing the reference power shape of the core. The REFORM process follows several steps. First the excess margin (the amount by which the margin to dryout exceeds the margin to trip) is determined for each channel in the core. The channel power in each fuel channel is then adjusted, in small increments, to minimize this excess margin. Since overall reactor power is to be conserved, the revised power shape is normalized. This has the effect of adding powers to the channels with excess margin and the removal of power from channels with small excess margins. The result is that, in the most limiting channels, the channel power is decreased, leading to a larger margin to dryout and increased permissible ROP setpoints.

In order to investigate the possibility of increasing of the trip setpoint in DUPIC core, the REFORM calculation has been performed. The calculation result shows that the trip setpoint increases to 125.73%, which is 3% higher than that of the normal trip setpoint. This is the theoretical improvement, and would have to be checked against operational considerations. The margin improvement indicated by ROVER-F is not currently required.

Table 4.1 Uncertainty Data for DUPIC Core Analysis

Uncertainty	Value (%)
Detector Random	2.60
Channel Random	1.97
Common Random	4.18
Bias	+0.14




Table 4.2 Trip Setpoint for Single Detector Failure

SDS1 Detector		SDS2 Detector	
Detector	Setpoint	Detector	Setpoint
1D	1.2336	1G	1.2336
2D	1.2336	2G	1.2226
3D	1.2336	3G	1.2334
4D	1.2336	4G	1.2332
5D	1.2336	5G	1.2336
6D	1.2336	6G	1.2336
7D	1.2336	7G	1.2100
8D	1.2336	8G	1.2202
9D	1.2336		
10D	1.2336		
11D	1.2254		
12D	1.2336		
1E	1.2159	1H	1.2332
2E	1.2336	2H	1.2312
3E	1.2336	3H	1.2165
4E	1.2336	4H	1.2111
5E	1.2336	5H	1.2323
6E	1.2336	6H	1.2336
7E	1.2336	7H	1.1204
8E	1.2336	8H	1.2002
9E	1.2336		
10E	1.2336		
11E	1.2336		
1F	1.2336	1J	1.2333
2F	1.2336	2J	1.2326
3F	1.2336	3J	1.2215
4F	1.2336	4J	1.1689
5F	1.2336	5J	1.2336
6F	1.2336	6J	1.2336
7F	1.2336	7J	1.1947
8F	1.2336	8J	1.1960
9F	1.2336		
10F	1.2336		
11F	1.2336		

5. SUMMARY AND FUTURE WORKS

The ROP assessments have been performed for CANDU 6 reactor with the DUPIC fuel. First, the validation calculation was performed for natural uranium core by comparing the results of the WIMS/RFSP/ROVER-F calculation with the PPV/RFSP/ ROVER-F one.

The validation calculation has shown that the difference between WIMS/RFSP/ROVER-F and PPV/RFSP/ROVER-F calculation is less than 1%, and therefore, it is expected that the WIMS-based calculation has the validity to be used for ROP system analysis of the CANDU 6 core.

Then, the probabilistic ROP assessment was carried out for the DUPIC fuel CANDU core. The probabilistic ROP assessment for the DUPIC core has shown that the ROP trip setpoint of the DUPIC core is almost the same as that of the natural uranium core. The maximum decrease in the trip setpoint for a single detector failure is $\sim 11\%$. However, the trip setpoint can be increased by 3% through the reforming of the channel power distribution.

Consequently, it is expected that the loading of the DUPIC fuel in a CANDU 6 reactor does not cause any adverse effects on the ROP trip setpoint. In future, the harmonic tilt and startup after long shutdown cases should be included for this study.

REFERENCES

1. C.M. Bailey and F.A.R. Laratta, "Design and Assessment of the Neutron Overpower Trips in the 600 MWe CANDU-PHW Reactors", TDAI-315, AECL, 1982.
2. C.M. Bailey and F.A.R. Laratta, "Final Assessment of the Point Lepreau Neutron Overpower Trips", TDAI-322, AECL, 1982.
3. M.R. Solard et al., "NUCIRC Code Validation; Versions: NUCIRC-MOD1.501, NUCIRC-MOD1.503", TTR-301, AECL, 1991.
4. C.M. Bailey and G. Gomez, "ROPT Error Analysis for Wolsong-1", TTR-289 Part 3 (W1) Rev. 1, 1995.
5. G. Gomez, "ROVER/REFORM: User's Guide - ROP Assessment and Channel Power Optimization Model", TTR-270, AECL, 1990.
6. C.M. Bailey and F.A.R. Laratta, "Design of the Bruce B ROP Systems", TDAI-284, AECL, 1982
7. C.M. Bailey and F.A.R. Laratta, Probabilistic Assessment and Design of Overpower Trips in CANDU Reactors, AECL-7550, 1983.
8. L.K.H. Leung, Critical Heat Flux for Heavy Water, COG-90-86 (ARD-TD-243), AECL, 1990.
9. J.V. Donnelly, "WIMS-CRNL: A Users Manual for the Chalk River Version of WIMS", AECL-8955, AECL, 1986.
10. D. B. Miller and E.S.Y. Tin, "POWDERPUFS-V Users Manual", TDAI-31 Par 2, AECL, 1976.
11. D. A. Jenkins and B. Rouben, "Reactor Fuelling Simulation Program - RFSP: User's Manual for Microcomputer Version", TTR-321, AECL, 1991.
12. J. Pitre, "ROVER-F Manual", TTR-605 (Rev. 1), AECL, 1999.
13. F.A.R. Laratta et al., "Design and Assessment of the Replacement ROPT System for Wolsong-1", TTR-289 Part 1 (W1), AECL, 1995.
14. J. W. Park et al., "Compatibility Analysis of DUPIC Fuel - Part 4: Thermal- Hydraulic Analysis", KAERI/TR-1607/2000, KAERI, 2000.

APPENDIX

Table A.1 Master List of Design Basis Cases

STEADY-STATE CASES WITH AND WITHOUT SPATIAL CONTROL

CASE NUMBER	FILE NAME	DESCRIPTION	AVZL	POWER (%FP)	S.C.	REF
1	SSSC50	STEADY-STATE WITH S.C	50.0	100.0	N	1
2	SSSC20	STEADY-STATE WITH S.C	50.0	100.0	Y	1
3	SSSC40	STEADY-STATE WITH S.C	50.0	100.0	Y	1
4	SSSC60	STEADY-STATE WITH S.C	50.0	100.0	Y	1
5	SSSC80	STEADY-STATE WITH S.C	50.0	100.0	Y	1
6	SSNC10	STEADY-STATE WITHOUT S.C	50.0	100.0	N	1
7	SSNC20	STEADY-STATE WITHOUT S.C	50.0	100.0	N	1
8	SSNC80	STEADY-STATE WITHOUT S.C	50.0	100.0	N	1
9	SSNC90	STEADY-STATE WITHOUT S.C	50.0	100.0	N	1

ZONE DRAINS FROM 20%, 50% AND 80%

CASE NUMBER	FILE NAME	DESCRIPTION	AVZL	POWER (%FP)	S.C.	REF
10	D01C20	ZONE DRAIN 01 FROM 20%	50.0	100.0	Y	1
11	D02C20	ZONE DRAIN 02 FROM 20%	50.0	100.0	Y	1
12	D03C20	ZONE DRAIN 03 FROM 20%	50.0	100.0	Y	1
13	D04C20	ZONE DRAIN 04 FROM 20%	50.0	100.0	Y	1
14	D05C20	ZONE DRAIN 05 FROM 20%	50.0	100.0	Y	1
15	D06C20	ZONE DRAIN 06 FROM 20%	50.0	100.0	Y	1
16	D07C20	ZONE DRAIN 07 FROM 20%	50.0	100.0	Y	1
17	D08C20	ZONE DRAIN 08 FROM 20%	50.0	100.0	Y	1
18	D09C20	ZONE DRAIN 09 FROM 20%	50.0	100.0	Y	1
19	D10C20	ZONE DRAIN 10 FROM 20%	50.0	100.0	Y	1
20	D11C20	ZONE DRAIN 11 FROM 20%	50.0	100.0	Y	1
21	D12C20	ZONE DRAIN 12 FROM 20%	50.0	100.0	Y	1
22	D13C20	ZONE DRAIN 13 FROM 20%	50.0	100.0	Y	1
23	D14C20	ZONE DRAIN 14 FROM 20%	50.0	100.0	Y	1
24	D01C50	ZONE DRAIN 01 FROM 50%	50.0	100.0	Y	1
25	D02C50	ZONE DRAIN 02 FROM 50%	50.0	100.0	Y	1
26	D03C50	ZONE DRAIN 03 FROM 50%	50.0	100.0	Y	1
27	D04C50	ZONE DRAIN 04 FROM 50%	50.0	100.0	Y	1
28	D05C50	ZONE DRAIN 05 FROM 50%	50.0	100.0	Y	1
29	D06C50	ZONE DRAIN 06 FROM 50%	50.0	100.0	Y	1
30	D07C50	ZONE DRAIN 07 FROM 50%	50.0	100.0	Y	1
31	D08C50	ZONE DRAIN 08 FROM 50%	50.0	100.0	Y	1
32	D09C50	ZONE DRAIN 09 FROM 50%	50.0	100.0	Y	1
33	D10C50	ZONE DRAIN 10 FROM 50%	50.0	100.0	Y	1
34	D11C50	ZONE DRAIN 11 FROM 50%	50.0	100.0	Y	1
35	D12C50	ZONE DRAIN 12 FROM 50%	50.0	100.0	Y	1
36	D13C50	ZONE DRAIN 13 FROM 50%	50.0	100.0	Y	1
37	D14C50	ZONE DRAIN 14 FROM 50%	50.0	100.0	Y	1
38	D01C80	ZONE DRAIN 01 FROM 80%	50.0	100.0	Y	1
39	D02C80	ZONE DRAIN 02 FROM 80%	50.0	100.0	Y	1
40	D03C80	ZONE DRAIN 03 FROM 80%	50.0	100.0	Y	1
41	D04C80	ZONE DRAIN 04 FROM 80%	50.0	100.0	Y	1
42	D05C80	ZONE DRAIN 05 FROM 80%	50.0	100.0	Y	1
43	D06C80	ZONE DRAIN 06 FROM 80%	50.0	100.0	Y	1
44	D07C80	ZONE DRAIN 07 FROM 80%	50.0	100.0	Y	1
45	D08C80	ZONE DRAIN 08 FROM 80%	50.0	100.0	Y	1
46	D09C80	ZONE DRAIN 09 FROM 80%	50.0	100.0	Y	1
47	D10C80	ZONE DRAIN 10 FROM 80%	50.0	100.0	Y	1
48	D11C80	ZONE DRAIN 11 FROM 80%	50.0	100.0	Y	1
49	D12C80	ZONE DRAIN 12 FROM 80%	50.0	100.0	Y	1
50	D13C80	ZONE DRAIN 13 FROM 80%	50.0	100.0	Y	1
51	D14C80	ZONE DRAIN 14 FROM 80%	50.0	100.0	Y	1

ZONE DRAIN FROM 50% WITHOUT S.C.

CASE NUMBER	FILE NAME	DESCRIPTION	AVZL	POWER (%FP)	S.C.	REF
52	D01N50	ZONE DRAIN 01 FROM 50%	50.0	100.0	N	1
53	D02N50	ZONE DRAIN 02 FROM 50%	50.0	100.0	N	1
54	D03N50	ZONE DRAIN 03 FROM 50%	50.0	100.0	N	1
55	D04N50	ZONE DRAIN 04 FROM 50%	50.0	100.0	N	1
56	D05N50	ZONE DRAIN 05 FROM 50%	50.0	100.0	N	1
57	D06N50	ZONE DRAIN 06 FROM 50%	50.0	100.0	N	1
58	D07N50	ZONE DRAIN 07 FROM 50%	50.0	100.0	N	1
59	D08N50	ZONE DRAIN 08 FROM 50%	50.0	100.0	N	1
60	D09N50	ZONE DRAIN 09 FROM 50%	50.0	100.0	N	1
61	D10N50	ZONE DRAIN 10 FROM 50%	50.0	100.0	N	1
62	D11N50	ZONE DRAIN 11 FROM 50%	50.0	100.0	N	1
63	D12N50	ZONE DRAIN 12 FROM 50%	50.0	100.0	N	1
64	D13N50	ZONE DRAIN 13 FROM 50%	50.0	100.0	N	1
65	D14N50	ZONE DRAIN 14 FROM 50%	50.0	100.0	N	1

SINGLE ADJUSTER WITHDRAWN WITH SPATIAL CONTROL

CASE NUMBER	FILE NAME	DESCRIPTION	AVZL	POWER (%FP)	S.C.	REF
66	AJFO01	ADJUSTER 01 FULL-OUT	50.0	100.0	Y	1
67	AJFO02	ADJUSTER 02 FULL-OUT	50.0	100.0	Y	1
68	AJFO03	ADJUSTER 03 FULL-OUT	50.0	100.0	Y	1
69	AJFO04	ADJUSTER 04 FULL-OUT	50.0	100.0	Y	1
70	AJFO05	ADJUSTER 05 FULL-OUT	50.0	100.0	Y	1
71	AJFO06	ADJUSTER 06 FULL-OUT	50.0	100.0	Y	1
72	AJFO07	ADJUSTER 07 FULL-OUT	50.0	100.0	Y	1
73	AJFO08	ADJUSTER 08 FULL-OUT	50.0	100.0	Y	1
74	AJFO09	ADJUSTER 09 FULL-OUT	50.0	100.0	Y	1
75	AJFO10	ADJUSTER 10 FULL-OUT	50.0	100.0	Y	1
76	AJFO11	ADJUSTER 11 FULL-OUT	50.0	100.0	Y	1
77	AJFO12	ADJUSTER 12 FULL-OUT	50.0	100.0	Y	1
78	AJFO13	ADJUSTER 13 FULL-OUT	50.0	100.0	Y	1
79	AJFO14	ADJUSTER 14 FULL-OUT	50.0	100.0	Y	1
80	AJFO15	ADJUSTER 15 FULL-OUT	50.0	100.0	Y	1
81	AJFO16	ADJUSTER 16 FULL-OUT	50.0	100.0	Y	1
82	AJFO17	ADJUSTER 17 FULL-OUT	50.0	100.0	Y	1
83	AJFO18	ADJUSTER 18 FULL-OUT	50.0	100.0	Y	1
84	AJFO19	ADJUSTER 19 FULL-OUT	50.0	100.0	Y	1
85	AJFO20	ADJUSTER 20 FULL-OUT	50.0	100.0	Y	1
86	AJFO21	ADJUSTER 21 FULL-OUT	50.0	100.0	Y	1
87	AJHO01	ADJUSTER 01 HALF-OUT	50.0	100.0	Y	1
88	AJHO02	ADJUSTER 02 HALF-OUT	50.0	100.0	Y	1
89	AJHO03	ADJUSTER 03 HALF-OUT	50.0	100.0	Y	1
90	AJHO04	ADJUSTER 04 HALF-OUT	50.0	100.0	Y	1
91	AJHO05	ADJUSTER 05 HALF-OUT	50.0	100.0	Y	1
92	AJHO06	ADJUSTER 06 HALF-OUT	50.0	100.0	Y	1
93	AJHO07	ADJUSTER 07 HALF-OUT	50.0	100.0	Y	1
94	AJHO08	ADJUSTER 08 HALF-OUT	50.0	100.0	Y	1
95	AJHO09	ADJUSTER 09 HALF-OUT	50.0	100.0	Y	1
96	AJHO10	ADJUSTER 10 HALF-OUT	50.0	100.0	Y	1
97	AJHO11	ADJUSTER 11 HALF-OUT	50.0	100.0	Y	1
98	AJHO12	ADJUSTER 12 HALF-OUT	50.0	100.0	Y	1
99	AJHO13	ADJUSTER 13 HALF-OUT	50.0	100.0	Y	1
100	AJHO14	ADJUSTER 14 HALF-OUT	50.0	100.0	Y	1
101	AJHO15	ADJUSTER 15 HALF-OUT	50.0	100.0	Y	1
102	AJHO16	ADJUSTER 16 HALF-OUT	50.0	100.0	Y	1
103	AJHO17	ADJUSTER 17 HALF-OUT	50.0	100.0	Y	1
104	AJHO18	ADJUSTER 18 HALF-OUT	50.0	100.0	Y	1
105	AJHO19	ADJUSTER 19 HALF-OUT	50.0	100.0	Y	1
106	AJHO20	ADJUSTER 20 HALF-OUT	50.0	100.0	Y	1
107	AJHO21	ADJUSTER 21 HALF-OUT	50.0	100.0	Y	1

MCA CASES

CASE NUMBER	FILE NAME	DESCRIPTION	AVZL	POWER (%FP)	S.C.	REF
108	MCAC1H	MCA 1ST BANK HALF-IN	50.0	100.0	Y	1
109	MCAC1F	MCA 1ST BANK FULL-IN	50.0	100.0	Y	1
110	MCAC2H	MCA 1ST FI & 2ND HI	50.0	100.0	Y	1
111	MCAC2F	MCA 1ST FI & 2ND HI	50.0	100.0	Y	1
112	MCAN1H	MCA 1ST BANK HALF-IN	50.0	100.0	N	1
113	MCAN1F	MCA 1ST BANK FULL-IN	50.0	100.0	N	1
114	MCAN2H	MCA 1ST FI & 2ND HI	50.0	100.0	N	1
115	MCAN2F	MCA 1ST FI & 2ND FI	50.0	100.0	N	1
116	MCAS1	MCA ROD 01 STUCK-IN	50.0	100.0	Y	1
117	MCAS12	MCA ROD 02 STUCK-IN	50.0	100.0	Y	1
118	MCAS13	MCA ROD 03 STUCK-IN	50.0	100.0	Y	1
119	MCAS14	MCA ROD 04 STUCK-IN	50.0	100.0	Y	1

ZONE INDUCED TILTS

CASE NUMBER	FILE NAME	DESCRIPTION	AVZL	POWER (%FP)	S.C.	REF
120	ZT1ATB	1ST AZIMUTHAL TOB/BOTTOM	50.0	100.0	N	1
121	ZT1ABT	1ST AZIMUTHAL BOTTOM/TOP	50.0	100.0	N	1
122	ZTSESE	1ST AZIMUTHAL SIDE/SIDE	50.0	100.0	N	1
123	ZTSESF	1ST AZIMUTHAL SIDE/SIDE	50.0	100.0	N	1
124	ZTEFEE	1ST AXIAL END/END	50.0	100.0	N	1
125	ZTEEEF	1ST AXIAL END/END	50.0	100.0	N	1
126	ZTT045	1ST AZIMUTHAL TOP AT 045	50.0	100.0	N	1
127	ZTT135	1ST AZIMUTHAL TOP AT 135	50.0	100.0	N	1
128	ZTT225	1ST AZIMUTHAL TOP AT 225	50.0	100.0	N	1
129	ZTT315	1ST AZIMUTHAL TOP AT 315	50.0	100.0	N	1
130	ZT2A01	2ND AZIMUTHAL 135,315 HI	50.0	100.0	N	1
131	ZT2A02	2ND AZIMUTHAL 045,225 HI	50.0	100.0	N	1
132	ZT2A03	2ND AZIMUTHAL T/B HI	50.0	100.0	N	1
133	ZT2A04	2ND AZIMUTHAL SIDES HI	50.0	100.0	N	1
134	ZTAX01	1ST AZIMUTHAL-AXIAL S=HI	50.0	100.0	N	1
135	ZTAX02	1ST AZIMUTHAL-AXIAL S=LO	50.0	100.0	N	1
136	ZTAX03	1ST AZIMUTHAL-AXIAL T=HI	50.0	100.0	N	1
137	ZTAX04	1ST AZIMUTHAL-AXIAL T=LO	50.0	100.0	N	1
138	ZT1R01	1ST RADIAL CENTER HI	50.0	100.0	N	1
139	ZT1R02	1ST RADIAL OUTER HI	50.0	100.0	N	1

HARMONIC TILTS

CASE NUMBER	FILE NAME	DESCRIPTION	AVZL	POWER (%FP)	S.C.	REF
140	HTTB00	HARMONIC TILT TOP/BOTTOM	50.0	100.0	N	1
141	HTTB01	HARMONIC TILT TOP/BOTTOM	50.0	100.0	N	1
142	HTTB02	HARMONIC TILT TOP/BOTTOM	50.0	100.0	N	1
143	HTTB03	HARMONIC TILT TOP/BOTTOM	50.0	100.0	N	1
144	HTTB04	HARMONIC TILT TOP/BOTTOM	50.0	100.0	N	1
145	HTSS00	HARMONIC TILT SIDE/SIDE	50.0	100.0	N	1
146	HTSS01	HARMONIC TILT SIDE/SIDE	50.0	100.0	N	1
147	HTSS02	HARMONIC TILT SIDE/SIDE	50.0	100.0	N	1
148	HTSS03	HARMONIC TILT SIDE/SIDE	50.0	100.0	N	1
149	HTSS04	HARMONIC TILT SIDE/SIDE	50.0	100.0	N	1

STARTUP AFTER SHORT SHUTDOWN (38 MIN)

CASE NUMBER	FILE NAME	DESCRIPTION	AVZL	POWER (%FP)	S.C.	REF
150	SSSD01	ALL BANKS OUT/Xe @ 38.1 MIN	50.0	100.0	N	1
151	SSSD02	ALL BANKS OUT/Xe @ 22.3 MIN	50.0	100.0	Y	1
152	SSSD03	BANK 7 FULL-IN/NO TIMESTEP	50.0	100.0	Y	1
153	SSSD04	BANK 7 FULL-IN/Xe @ 27.4 MIN	50.0	100.0	Y	1
154	SSSD05	BANK 6 FULL-IN/NO TIMESTEP	50.0	100.0	Y	1
155	SSSD06	BANK 6 FULL-IN/Xe @ 26.7 MIN	50.0	100.0	Y	1
156	SSSD07	BANK 5 FULL-IN/NO TIMESTEP	50.0	100.0	Y	1
157	SSSD08	BANK 5 FULL-IN/Xe @ 26.5 MIN	50.0	100.0	Y	1
158	SSSD09	BANK 4 FULL-IN/NO TIMESTEP	50.0	100.0	Y	1
159	SSSD10	BANK 4 FULL-IN/Xe @ 23.5 MIN	50.0	100.0	Y	1
160	SSSD11	BANK 3 FULL-IN/NO TIMESTEP	50.0	100.0	Y	1
161	SSSD12	BANK 3 FULL-IN/Xe @ 27.8 MIN	50.0	100.0	Y	1
162	SSSD13	BANK 2 FULL-IN/NO TIMESTEP	50.0	100.0	Y	1
163	SSSD14	BANK 2 FULL-IN/Xe @ 43.6 MIN	50.0	100.0	Y	1
164	SSSD15	BANK 1 FULL-IN/NO TIMESTEP	50.0	100.0	Y	1
165	SSSD16	BANK 1 FULL-IN/Xe @ 90.0 MIN	50.0	100.0	Y	1
166	SSSD17	ALL BANKS IN/Xe @ 180. MIN	50.0	100.0	Y	1
167	SSSD18	ALL BANKS IN/Xe @ 270. MIN	50.0	100.0	Y	1

STARTUP AFTER POISON OUT

CASE NUMBER	FILE NAME	DESCRIPTION	AVZL	POWER (%FP)	S.C.	REF
168	SA4400	ALL BANKS OUT/Xe @ 36. HRS	50.0	100.0	-	1
169	SA4401	ALL BANKS OUT/Xe @ 46.4 MIN	50.0	100.0	N	1
170	SA4402	ALL BANKS OUT/Xe @ 5.3 MIN	50.0	100.0	Y	1
171	SA4403	BANK 7 FULL-IN	50.0	100.0	Y	1
172	SA4404	BANK 7 FULL-IN/Xe @ 5.2 MIN	50.0	100.0	Y	1
173	SA4405	BANK 6 FULL-IN	50.0	100.0	Y	1
174	SA4406	BANK 6 FULL-IN/Xe @ 4.3 MIN	50.0	100.0	Y	1
175	SA4407	BANK 5 FULL-IN	50.0	100.0	Y	1
176	SA4408	BANK 5 FULL-IN/Xe @ 4.3 MIN	50.0	100.0	Y	1
177	SA4409	BANK 4 FULL-IN	50.0	100.0	Y	1
178	SA4410	BANK 4 FULL-IN/Xe @ 3.9 MIN	50.0	100.0	Y	1
179	SA4411	BANK 3 FULL-IN	50.0	100.0	Y	1
180	SA4412	BANK 3 FULL-IN/Xe @ 3.9 MIN	50.0	100.0	Y	1
181	SA4413	BANK 2 FULL-IN	50.0	100.0	Y	1
182	SA4414	BANK 2 FULL-IN/Xe @4.2 MIN	50.0	100.0	Y	1
183	SA4415	BANK 1 FULL-IN	50.0	100.0	Y	1
184	SA4416	BANK 1 FI+0.5PPM/Xe @ 12.9 MIN	50.0	100.0	Y	1
185	SA4417	ALL BANKS IN+2.0PPM/Xe @ 83.7 MIN	50.0	100.0	Y	1
186	SA4418	ALL BANKS IN+2.0PPM/Xe @ 263.7MIN	50.0	100.0	Y	1

STARTUP AFTER PROLONGED SHUTDOWN

CASE NUMBER	FILE NAME	DESCRIPTION	AVZL	POWER (%FP)	S.C.	REF
187	SPSD01	00% XENON TIME 00 HOURS 3.374 ppm OF BORON	50.0	100.0	Y	1
188	SPSD02	00% XENON TIME 00 HOURS 3.374 ppm OF BORON	50.0	100.0	Y	1
189	SPSD03	00% XENON TIME 00 HOURS 3.374 ppm OF BORON	50.0	100.0	Y	1
190	SPSD04	00% XENON TIME 00 HOURS 3.374 ppm OF BORON	50.0	100.0	Y	1

STEBBACK TO 60% FP

CASE NUMBER	FILE NAME	DESCRIPTION	AVZL	POWER (%FP)	S.C.	REF
191	SBCK01	ALL BANKS IN/Xe @ 12.3 MIN	50.0	100.0	Y	1
192	SBCK02	BANK 1 OUT	50.0	100.0	Y	1
193	SBCK03	BANK 1 OUT/Xe @ 10.5 MIN	50.0	100.0	Y	1
194	SBCK04	BANK 2 OUT +	50.0	100.0	Y	1
195	SBCK05	BANK 2 OUT/Xe @ 18.3 MIN	50.0	100.0	Y	1
196	SBCK06	BANK 3 OUT	50.0	100.0	Y	1
197	SBCK07	BANK 3 OUT/Xe @ 28.5 MIN	50.0	100.0	Y	1
198	SBCK08	BANK 4 OUT	50.0	100.0	Y	1
199	SBCK09	BANK 4 OUT/Xe @ 310.9 MIN	50.0	100.0	Y	1
200	SBCK10	BANK 4 IN	50.0	100.0	Y	1
201	SBCK11	BANK 4 IN/Xe @ 270.4 MIN	50.0	100.0	Y	1

SHIM CASES

CASE NUMBER	FILE NAME	DESCRIPTION	AVZL	POWER (%FP)	S.C.	REF
202	SHIM01	ALL BANKS IN/SS Xe	50.0	100.0	Y	1
203	SHIM02	BANK 1 OUT	50.0	100.0	Y	1
204	SHIM03	BANK 1 OUT/Xe @240. MIN	50.0	100.0	Y	1
205	SHIM04	BANK 1 OUT/SS Xe	50.0	100.0	Y	1
206	SHIM05	BANK 2 OUT	50.0	100.0	Y	1
207	SHIM06	BANK 2 OUT/Xe A 240.MIN	50.0	100.0	Y	1
208	SHIM07	BANK 2 OUT/SS Xe	50.0	100.0	Y	1
209	SHIM08	BANK 3 OUT	50.0	100.0	Y	1
210	SHIM09	BANK 3 OUT/Xe @ 240. MIN	50.0	100.0	Y	1
211	SHIM10	BANK 3 OUT/SS Xe	50.0	100.0	Y	1
212	SHIM11	BANK 4 OUT	50.0	100.0	Y	1
213	SHIM12	BANK 4 OUT/Xe @ 240.0 MIN	50.0	100.0	Y	1
214	SHIM13	BANK 4 OUT/SS Xe	50.0	100.0	Y	1
215	SHIM14	BANK 5 OUT	50.0	100.0	Y	1
216	SHIM15	BANK 5 OUT/Xe @ 240.0 MIN	50.0	100.0	Y	1
217	SHIM16	BANK 5 OUT/SS Xe	50.0	100.0	Y	1
218	SHIM17	BANK 6 OUT	50.0	100.0	Y	1
219	SHIM18	BANK 6 OUT/SS Xe	50.0	100.0	Y	1
220	SHIM19	BANK 7 OUT	50.0	100.0	Y	1
221	SHIM20	BANK 7 OUT/SS Xe	50.0	100.0	Y	1

ADJUSTER BANKS AND MCA'S HALF OUT

CASE NUMBER	FILE NAME	DESCRIPTION	AVZL	POWER (%FP)	S.C.	REF
222	ABHO01	STARTUP BANK 7 HALF-IN	50.0	100.0	N	1
223	ABHO02	STARTUP BANK 6 HALF-IN	50.0	100.0	N	1
224	ABHO03	STARTUP BANK 5 HALF-IN	50.0	100.0	N	1
225	ABHO04	STARTUP BANK 4 HALF-IN	50.0	100.0	N	1
226	ABHO05	STARTUP BANK 3 HALF-IN	50.0	100.0	N	1
227	ABHO06	SHIM BANK 1 HALF-OUT	50.0	100.0	N	1
228	ABHO07	SHIM BANK 2 HALF-OUT	50.0	100.0	N	1
229	MCASH1	MCA ROD 1 HALF-IN	50.0	100.0	Y	1
230	MCASH2	MCA ROD 2 HALF-IN	50.0	100.0	Y	1
231	MCASH3	MCA ROD 3 HALF-IN	50.0	100.0	Y	1
232	MCASH4	MCA ROD 4 HALF-IN	50.0	100.0	Y	1




Table A.2 Calculation Result of PPV/RFSP/ROVER-F

ROVER-F Version 2.00 : Mon Nov 8 10:17:49 1999
Confidence Calculation

Echo Base Parameters

Number of Channels = 380
 Number of Cases = 232
 Number of CP Cases = 232
 Number of CCP Cases = 232
 Number of Det Cases = 232
 Number of Ripple Cases = 150
 Number of Bins = 21
 Number of Detector Sites = 58
 Number of Detectors = 58
 Number of Detector Channels = 6
 Number of Shutdown Systems = 2
 Number of Det Setpoint Plateaus = 4
 Number of x space meshes = 51
 Debug case ID = 1
 reading rover-case.data
 Basis Case Data DB_W1_DUP_0
 Reading 232 cases of 999 available.

reading rover-cp.data
 Reading 232 cases of 232 available.

reading rover-ccp.data
 Reading 232 cases of 232 available.

reading rover-rip.data
 Ripple data for Wolsong 1
 Reading 150 cases of 150 available.

reading rover-err.data
 Errors Data(DB_W1_TTR289)
 Detector Random Error = .0260
 Channel Random Error = .0149
 Common Random Error = .0418
 Systematic Error = .0014
 Low X Space Limit = .7000
 High X Space Limit = 1.2000
 Bins Width = .0050
 Trip Confidence Limit = .9800

Probability Mesh Parameters:
 21 Bins of Width : .0050 running from 1.0000 to 1.1050
 51 Mesh points of Width : .0100 running from .7000 to 1.2000

Reading Detector Data

W1 Flat Plateaus - 1H and 1J NOT Switched
 Detector Calibration Case = 1
 Channel 1 includes detectors 1-12 (1D -12D)

KAERI/TR-2511/2003

Channel 2 includes detectors13-23 (1E -11E)
 Channel 3 includes detectors24-34 (1F -11F)
 Channel 4 includes detectors35-42 (1G -8G)
 Channel 5 includes detectors43-50 (1H -8H)
 Channel 6 includes detectors51-58 (1J -8J)
 SDS 1 includes detector channels 1- 3
 SDS 2 includes detector channels 4- 6
 Detector 7G compensated with detector 3G
 Detector 8G compensated with detector 4G
 Detector 2H compensated with detector 5H
 Detector 7H compensated with detector 8H
 Detector 2J compensated with detector 3J
 Detector 8J compensated with detector 7J

#	Det	Setpoint	Boil Corr.	Fail	Site
1	1D	1.240000	-.008700	1	1
2	2D	1.240000	-.002300	1	2
3	3D	1.240000	-.002300	1	3
4	4D	1.240000	-.008300	1	4
5	5D	1.240000	-.008700	1	5
6	6D	1.240000	-.000700	1	6
7	7D	1.240000	-.000700	1	7
8	8D	1.240000	-.000700	1	8
9	9D	1.240000	-.000700	1	9
10	10D	1.240000	-.000700	1	10
11	11D	1.240000	-.000700	1	11
12	12D	1.240000	-.002300	1	12
13	1E	1.240000	-.002300	1	13
14	2E	1.240000	-.000700	1	14
15	3E	1.240000	-.000700	1	15
16	4E	1.240000	-.008300	1	16
17	5E	1.240000	-.008700	1	17
18	6E	1.240000	-.008300	1	18
19	7E	1.240000	-.008700	1	19
20	8E	1.240000	-.000700	1	20
21	9E	1.240000	-.002300	1	21
22	10E	1.240000	-.000700	1	22
23	11E	1.240000	-.002300	1	23
24	1F	1.240000	-.008700	1	24
25	2F	1.240000	-.008300	1	25
26	3F	1.240000	-.008700	1	26
27	4F	1.240000	-.002300	1	27
28	5F	1.240000	-.008700	1	28
29	6F	1.240000	-.008300	1	29
30	7F	1.240000	-.000700	1	30
31	8F	1.240000	.007300	1	31
32	9F	1.240000	-.002300	1	32
33	10F	1.240000	-.000700	1	33
34	11F	1.240000	.006000	1	34
35	1G	1.240000	-.008700	1	35
36	2G	1.240000	-.008700	1	36
37	3G	1.240000	.005500	1	37
38	4G	1.240000	.005500	1	38
39	5G	1.240000	-.008700	1	39
40	6G	1.240000	-.008700	1	40
41	7G	1.240000	.005500	1	41
42	8G	1.240000	.005500	1	42
43	1H	1.240000	-.008700	1	51
44	2H	1.240000	.005500	1	44
45	3H	1.240000	-.008700	1	45
46	4H	1.240000	-.008700	1	46
47	5H	1.240000	.005500	1	47
48	6H	1.240000	-.008700	1	48
49	7H	1.240000	.005500	1	49
50	8H	1.240000	.005500	1	50
51	1J	1.240000	-.008700	1	43
52	2J	1.240000	.005500	1	52
53	3J	1.240000	.005500	1	53
54	4J	1.240000	-.008700	1	54
55	5J	1.240000	-.008700	1	55
56	6J	1.240000	-.008700	1	56

KAERI/TR-2511/2003

57 7J 1.240000 .005500 1 57
 58 8J 1.240000 .005500 1 58

Reading Detector Readings

Reading 58 detectors of 58 sites available.
 Reading 232 cases of 232 available.
 Performing 7G with 3G compensation.
 Performing 8G with 4G compensation.
 Performing 2H with 5H compensation.
 Performing 7H with 8H compensation.
 Performing 2J with 3J compensation.
 Performing 8J with 7J compensation.

Performing Precalculation

reading cppf.data
 CPPF Data W1

Average CPPF = 1.0706
 reading rover-orif.data
 Nucirc Data (DB_W1_DUP_0)
 Completed Precalculation

Results

Case	CPRL	Avg. Cons.	SDS1
SDS2			
1 1 SSSC50 STEADY-STATE WITH S.C.	1.394336	1.020443	.999387
.999236 6D 3G			
37 37 D14C50 ZONE DRAIN 14 FROM 50%	1.350021	1.035591	.998359
.997461 10E 4J			
39 39 D02C80 ZONE DRAIN 02 FROM 80%	1.288055	1.042705	.999385
.991575 2E 2G			
42 42 D05C80 ZONE DRAIN 05 FROM 80%	1.260331	1.034663	.992885
.955936 4D 7J			
44 44 D07C80 ZONE DRAIN 07 FROM 80%	1.280216	1.033913	.995333
.978196 4E 4H			
46 46 D09C80 ZONE DRAIN 09 FROM 80%	1.281121	1.051178	.997264
.993562 6D 3H			
49 49 D12C80 ZONE DRAIN 12 FROM 80%	1.261377	1.039092	.996700
.964214 9E 8H			
51 51 D14C80 ZONE DRAIN 14 FROM 80%	1.288607	1.030578	.992883
.985867 10E 4G			
53 53 D02N50 ZONE DRAIN 02 FROM 50%	1.320378	1.048829	.999252
.996725 2E 7G			
58 58 D07N50 ZONE DRAIN 07 FROM 50%	1.318054	1.035807	.997710
.994978 3F 4H			
60 60 D09N50 ZONE DRAIN 09 FROM 50%	1.319606	1.050913	.998692
.997229 6D 3H			
65 65 D14N50 ZONE DRAIN 14 FROM 50%	1.319468	1.036770	.996794
.995963 9F 2J			
114 114 MCAN2H MCA 1ST FI & 2ND HI	1.041749	1.024332	.991849
.964652 11D 7H			
122 122 ZTSFSE 1ST AZIMUTHAL SIDE/SIDE	1.247081	1.037228	.993653
.990868 11E 1G			
123 123 ZTSESF 1ST AZIMUTHAL SIDE/SIDE	1.248250	1.044385	.996808
.993310 1D 2G			
130 130 ZT2A01 2ND AZIMUTHAL 135,315 HI	1.301482	1.051439	.998524
.995807 1D 2G			
131 131 ZT2A02 2ND AZIMUTHAL 045,225 HI	1.300313	1.039521	.995054
.994965 9F 7G			
152 152 SSSD03 BANK 7 FULL-IN/NO TIMESTEP	1.082631	1.030492	.997640
.973417 6F 4J			
171 171 SA4403 BANK 7 FULL-IN	1.208533	1.030256	.999224
.991729 3F 4J			
173 173 SA4405 BANK 6 FULL-IN	1.186291	1.029392	.961503
.960538 5F 4J			

KAERI/TR-2511/2003

174	174	SA4406	BANK 6 FULL-IN/Xe @ 4.3 MIN	1.203234	1.023040	.999274
	.999613	5F 4J				
177	177	SA4409	BANK 4 FULL-IN	1.302997	1.040742	.997302
	.995159	4F 7J				
178	178	SA4410	BANK 4 FULL-IN/Xe @ 3.9 MIN	1.272422	1.027372	.995873
	.974758	7D 4J				
195	195	SBCK05	BANK 2 OUT/Xe @ 18.3 MIN	1.327840	1.035960	.999714
	.997965	4F 7J				
196	196	SBCK06	BANK 3 OUT	1.250053	1.039790	.999121
	.991757	6F 4J				
197	197	SBCK07	BANK 3 OUT/Xe @ 28.5 MIN	1.262964	1.041612	.999033
	.994038	4F 4J				
222	222	ABHO01	STARTUP BANK 7 HALF-IN	1.005048	1.040352	.999983
	.997623	7E 4J				

25 Worst Cases.

42	D05C80	ZONE DRAIN 05 FROM 80%	.9929	.9559
173	SA4405	BANK 6 FULL-IN	.9615	.9605
49	D12C80	ZONE DRAIN 12 FROM 80%	.9967	.9642
114	MCAN2H	MCA 1ST FI & 2ND HI	.9918	.9647
152	SSSD03	BANK 7 FULL-IN/NO TIMESTEP	.9976	.9734
178	SA4410	BANK 4 FULL-IN/Xe @ 3.9 MIN	.9959	.9748
44	D07C80	ZONE DRAIN 07 FROM 80%	.9953	.9782
51	D14C80	ZONE DRAIN 14 FROM 80%	.9929	.9859
122	ZTSFSE	1ST AZIMUTHAL SIDE/SIDE	.9937	.9909
39	D02C80	ZONE DRAIN 02 FROM 80%	.9994	.9916
171	SA4403	BANK 7 FULL-IN	.9992	.9917
196	SBCK06	BANK 3 OUT	.9991	.9918
123	ZTSESF	1ST AZIMUTHAL SIDE/SIDE	.9968	.9933
46	D09C80	ZONE DRAIN 09 FROM 80%	.9973	.9936
197	SBCK07	BANK 3 OUT/Xe @ 28.5 MIN	.9990	.9940
131	ZT2A02	2ND AZIMUTHAL 045,225 HI	.9951	.9950
58	D07N50	ZONE DRAIN 07 FROM 50%	.9977	.9950
177	SA4409	BANK 4 FULL-IN	.9973	.9952
130	ZT2A01	2ND AZIMUTHAL 135,315 HI	.9985	.9958
65	D14N50	ZONE DRAIN 14 FROM 50%	.9968	.9960
53	D02N50	ZONE DRAIN 02 FROM 50%	.9993	.9967
60	D09N50	ZONE DRAIN 09 FROM 50%	.9987	.9972
37	D14C50	ZONE DRAIN 14 FROM 50%	.9984	.9975
222	ABHO01	STARTUP BANK 7 HALF-IN	1.0000	.9976
195	SBCK05	BANK 2 OUT/Xe @ 18.3 MIN	.9997	.9980

Minimum trip confidence = .9559 for case 42

Calculating Required Setpoint Adjustment
 Setpoint Adjustment = .9820 (.9800) Case : 42
 Base Setpoint Result = 1.2177

Table A.3 Calculation Result of WIMS/RFSP/ROVER-F

ROVER-F Version 2.00 : Mon Nov 8 11:03:34 1999
Confidence Calculation

Echo Base Parameters

Number of Channels = 380
 Number of Cases = 232
 Number of CP Cases = 232
 Number of CCP Cases = 232
 Number of Det Cases = 232
 Number of Ripple Cases = 150
 Number of Bins = 21
 Number of Detector Sites = 58
 Number of Detectors = 58
 Number of Detector Channels = 6
 Number of Shutdown Systems = 2
 Number of Det Setpoint Plateaus = 4
 Number of x space meshes = 51
 Debug case ID = 1
 reading rover-case.data
 Basis Case Data DB_W1_DUP_0
 Reading 232 cases of 999 available.

reading rover-cp.data
 Reading 232 cases of 232 available.

reading rover-ccp.data
 Reading 232 cases of 232 available.

reading rover-rip.data
 Ripple data for Wolsong 1
 Reading 150 cases of 150 available.

reading rover-err.data
 Errors Data(DB_W1_TTR289)
 Detector Random Error = .0260
 Channel Random Error = .0149
 Common Random Error = .0418
 Systematic Error = .0014
 Low X Space Limit = .7000
 High X Space Limit = 1.2000
 Bins Width = .0050
 Trip Confidence Limit = .9800

Probability Mesh Parameters:
 21 Bins of Width : .0050 running from 1.0000 to 1.1050
 51 Mesh points of Width : .0100 running from .7000 to 1.2000

Reading Detector Data

W1 Flat Plateaus - 1H and 1J NOT Switched
 Detector Calibration Case = 1
 Channel 1 includes detectors 1-12 (1D -12D)

KAERI/TR-2511/2003

Channel 2 includes detectors13-23 (1E -11E)
 Channel 3 includes detectors24-34 (1F -11F)
 Channel 4 includes detectors35-42 (1G -8G)
 Channel 5 includes detectors43-50 (1H -8H)
 Channel 6 includes detectors51-58 (1J -8J)
 SDS 1 includes detector channels 1- 3
 SDS 2 includes detector channels 4- 6
 Detector 7G compensated with detector 3G
 Detector 8G compensated with detector 4G
 Detector 2H compensated with detector 5H
 Detector 7H compensated with detector 8H
 Detector 2J compensated with detector 3J
 Detector 8J compensated with detector 7J

#	Det	Setpoint	Boil Corr.	Fail	Site
1	1D	1.240000	-.008700	1	1
2	2D	1.240000	-.002300	1	2
3	3D	1.240000	-.002300	1	3
4	4D	1.240000	-.008300	1	4
5	5D	1.240000	-.008700	1	5
6	6D	1.240000	-.000700	1	6
7	7D	1.240000	-.000700	1	7
8	8D	1.240000	-.000700	1	8
9	9D	1.240000	-.000700	1	9
10	10D	1.240000	-.000700	1	10
11	11D	1.240000	-.000700	1	11
12	12D	1.240000	-.002300	1	12
13	1E	1.240000	-.002300	1	13
14	2E	1.240000	-.000700	1	14
15	3E	1.240000	-.000700	1	15
16	4E	1.240000	-.008300	1	16
17	5E	1.240000	-.008700	1	17
18	6E	1.240000	-.008300	1	18
19	7E	1.240000	-.008700	1	19
20	8E	1.240000	-.000700	1	20
21	9E	1.240000	-.002300	1	21
22	10E	1.240000	-.000700	1	22
23	11E	1.240000	-.002300	1	23
24	1F	1.240000	-.008700	1	24
25	2F	1.240000	-.008300	1	25
26	3F	1.240000	-.008700	1	26
27	4F	1.240000	-.002300	1	27
28	5F	1.240000	-.008700	1	28
29	6F	1.240000	-.008300	1	29
30	7F	1.240000	-.000700	1	30
31	8F	1.240000	.007300	1	31
32	9F	1.240000	-.002300	1	32
33	10F	1.240000	-.000700	1	33
34	11F	1.240000	.006000	1	34
35	1G	1.240000	-.008700	1	35
36	2G	1.240000	-.008700	1	36
37	3G	1.240000	.005500	1	37
38	4G	1.240000	.005500	1	38
39	5G	1.240000	-.008700	1	39
40	6G	1.240000	-.008700	1	40
41	7G	1.240000	.005500	1	41
42	8G	1.240000	.005500	1	42
43	1H	1.240000	-.008700	1	51
44	2H	1.240000	.005500	1	44
45	3H	1.240000	-.008700	1	45
46	4H	1.240000	-.008700	1	46
47	5H	1.240000	.005500	1	47
48	6H	1.240000	-.008700	1	48
49	7H	1.240000	.005500	1	49
50	8H	1.240000	.005500	1	50
51	1J	1.240000	-.008700	1	43
52	2J	1.240000	.005500	1	52
53	3J	1.240000	.005500	1	53
54	4J	1.240000	-.008700	1	54
55	5J	1.240000	-.008700	1	55
56	6J	1.240000	-.008700	1	56

KAERI/TR-2511/2003

57 7J 1.240000 .005500 1 57
 58 8J 1.240000 .005500 1 58

Reading Detector Readings

Reading 58 detectors of 58 sites available.
 Reading 232 cases of 232 available.
 Performing 7G with 3G compensation.
 Performing 8G with 4G compensation.
 Performing 2H with 5H compensation.
 Performing 7H with 8H compensation.
 Performing 2J with 3J compensation.
 Performing 8J with 7J compensation.

Performing Precalculation

reading cppf.data
 CPPF Data W1

Average CPPF = 1.0706
 reading rover-orif.data
 Nucirc Data (DB_W1_DUP_0)
 Completed Precalculation

Results

Case	CPRL	Avg. Cons.	SDS1
SDS2			
1 1 SSSC50 STEADY-STATE WITH S.C.	1.369820	1.030835	.999099
.998877 6D 3G			
37 37 D14C50 ZONE DRAIN 14 FROM 50%	1.342749	1.033680	.997696
.996358 10E 4G			
39 39 D02C80 ZONE DRAIN 02 FROM 80%	1.254138	1.047924	.998724
.980224 2E 2G			
42 42 D05C80 ZONE DRAIN 05 FROM 80%	1.321333	1.032727	.999533
.994815 4D 7J			
44 44 D07C80 ZONE DRAIN 07 FROM 80%	1.271005	1.029804	.994233
.970054 9F 4H			
46 46 D09C80 ZONE DRAIN 09 FROM 80%	1.261530	1.040759	.992497
.987357 5D 3H			
49 49 D12C80 ZONE DRAIN 12 FROM 80%	1.320805	1.035371	.999837
.996091 10E 8H			
51 51 D14C80 ZONE DRAIN 14 FROM 80%	1.263583	1.033302	.989258
.980038 10E 1G			
53 53 D02N50 ZONE DRAIN 02 FROM 50%	1.295884	1.049199	.998295
.991499 2E 7G			
58 58 D07N50 ZONE DRAIN 07 FROM 50%	1.294957	1.044964	.996691
.991885 3F 4H			
60 60 D09N50 ZONE DRAIN 09 FROM 50%	1.286652	1.055838	.996440
.992331 6D 3H			
65 65 D14N50 ZONE DRAIN 14 FROM 50%	1.304970	1.036724	.995509
.994199 9F 2J			
114 114 MCAN2H MCA 1ST FI & 2ND HI	1.031774	1.030312	.998782
.989729 11D 7H			
122 122 ZTSFSE 1ST AZIMUTHAL SIDE/SIDE	1.214275	1.041828	.989290
.984092 11E 1G			
123 123 ZTSESF 1ST AZIMUTHAL SIDE/SIDE	1.207210	1.046220	.989658
.981221 1D 2G			
130 130 ZT2A01 2ND AZIMUTHAL 135,315 HI	1.275247	1.052517	.996174
.989044 1D 2G			
131 131 ZT2A02 2ND AZIMUTHAL 045,225 HI	1.283343	1.042180	.991632
.991670 9F 7G			
152 152 SSSD03 BANK 7 FULL-IN/NO TIMESTEP	1.101796	1.026248	.999826
.980611 6F 4J			
171 171 SA4403 BANK 7 FULL-IN	1.191923	1.023887	.999697
.983201 3F 4J			
173 173 SA4405 BANK 6 FULL-IN	1.266028	1.040944	.999068
.998280 8F 2H			

KAERI/TR-2511/2003

174	174	SA4406	BANK 6 FULL-IN/Xe @ 4.3 MIN	1.263860	1.042245	.999093
	.998354	8F 2H				
177	177	SA4409	BANK 4 FULL-IN	1.341410	1.027288	.999098
	.997958	11F 7J				
178	178	SA4410	BANK 4 FULL-IN/Xe @ 3.9 MIN	1.342183	1.027765	.999152
	.998046	11F 7J				
195	195	SBCK05	BANK 2 OUT/Xe @ 18.3 MIN	1.327127	1.036370	.999769
	.998193	4F 7J				
196	196	SBCK06	BANK 3 OUT	1.276083	1.037626	.999652
	.996550	6F 4J				
197	197	SBCK07	BANK 3 OUT/Xe @ 28.5 MIN	1.288818	1.033968	.999539
	.996713	4F 7J				
222	222	ABHO01	STARTUP BANK 7 HALF-IN	.985926	1.037645	.999998
	.994597	5D 4J				

25 Worst Cases.

44	D07C80	ZONE DRAIN 07 FROM 80%	.9942	.9701
51	D14C80	ZONE DRAIN 14 FROM 80%	.9893	.9800
39	D02C80	ZONE DRAIN 02 FROM 80%	.9987	.9802
152	SSSD03	BANK 7 FULL-IN/NO TIMESTEP	.9998	.9806
123	ZTSESF	1ST AZIMUTHAL SIDE/SIDE	.9897	.9812
171	SA4403	BANK 7 FULL-IN	.9997	.9832
122	ZTSFSE	1ST AZIMUTHAL SIDE/SIDE	.9893	.9841
46	D09C80	ZONE DRAIN 09 FROM 80%	.9925	.9874
130	ZT2A01	2ND AZIMUTHAL 135,315 HI	.9962	.9890
114	MCAN2H	MCA 1ST FI & 2ND HI	.9988	.9897
53	D02N50	ZONE DRAIN 02 FROM 50%	.9983	.9915
131	ZT2A02	2ND AZIMUTHAL 045,225 HI	.9916	.9917
58	D07N50	ZONE DRAIN 07 FROM 50%	.9967	.9919
60	D09N50	ZONE DRAIN 09 FROM 50%	.9964	.9923
65	D14N50	ZONE DRAIN 14 FROM 50%	.9955	.9942
222	ABHO01	STARTUP BANK 7 HALF-IN	1.0000	.9946
42	D05C80	ZONE DRAIN 05 FROM 80%	.9995	.9948
49	D12C80	ZONE DRAIN 12 FROM 80%	.9998	.9961
37	D14C50	ZONE DRAIN 14 FROM 50%	.9977	.9964
196	SBCK06	BANK 3 OUT	.9997	.9966
197	SBCK07	BANK 3 OUT/Xe @ 28.5 MIN	.9995	.9967
177	SA4409	BANK 4 FULL-IN	.9991	.9980
178	SA4410	BANK 4 FULL-IN/Xe @ 3.9 MIN	.9992	.9980
195	SBCK05	BANK 2 OUT/Xe @ 18.3 MIN	.9998	.9982
173	SA4405	BANK 6 FULL-IN	.9991	.9983

Minimum trip confidence = .9701 for case 44

Calculating Required Setpoint Adjustment
 Setpoint Adjustment = .9911 (.9800) Case : 44
 Base Setpoint Result = 1.2290

Table A.4 ROP Assessment Result for DUPIC Core

ROVER-F Version 2.00 : Mon Nov 8 10:06:02 1999
Confidence Calculation

Echo Base Parameters

Number of Channels = 380
 Number of Cases = 232
 Number of CP Cases = 232
 Number of CCP Cases = 232
 Number of Det Cases = 232
 Number of Ripple Cases = 121
 Number of Bins = 21
 Number of Detector Sites = 58
 Number of Detectors = 58
 Number of Detector Channels = 6
 Number of Shutdown Systems = 2
 Number of Det Setpoint Plateaus = 4
 Number of x space meshes = 51
 Debug case ID = -1
 reading rover-case.data
 Basis Case Data DB_W1_DUP_0
 Reading 232 cases of 999 available.

reading rover-cp.data
 Reading 232 cases of 232 available.

reading rover-ccp.data
 Reading 232 cases of 232 available.

reading rover-rip.data
 Ripple data for DUPIC core
 Reading 121 cases of 121 available.

reading rover-err.data
 Errors Data(CHRAN BY DATA OF JWPARK)
 Detector Random Error = .0260
 Channel Random Error = .0197
 Common Random Error = .0418
 Systematic Error = .0014
 Low X Space Limit = .7000
 High X Space Limit = 1.2000
 Bins Width = .0050
 Trip Confidence Limit = .9800

Probability Mesh Parameters:
 21 Bins of Width : .0050 running from 1.0000 to 1.1050
 51 Mesh points of Width : .0100 running from .7000 to 1.2000

Reading Detector Data

W1 Flat Plateaus - 1H and 1J NOT Switched
 Detector Calibration Case = 1
 Channel 1 includes detectors 1-12 (1D -12D)

KAERI/TR-2511/2003

Channel 2 includes detectors13-23 (1E -11E)
 Channel 3 includes detectors24-34 (1F -11F)
 Channel 4 includes detectors35-42 (1G -8G)
 Channel 5 includes detectors43-50 (1H -8H)
 Channel 6 includes detectors51-58 (1J -8J)
 SDS 1 includes detector channels 1- 3
 SDS 2 includes detector channels 4- 6
 Detector 7G compensated with detector 3G
 Detector 8G compensated with detector 4G
 Detector 2H compensated with detector 5H
 Detector 7H compensated with detector 8H
 Detector 2J compensated with detector 3J
 Detector 8J compensated with detector 7J

#	Det	Setpoint	Boil Corr.	Fail	Site
1	1D	1.240000	-.008700	1	1
2	2D	1.240000	-.002300	1	2
3	3D	1.240000	-.002300	1	3
4	4D	1.240000	-.008300	1	4
5	5D	1.240000	-.008700	1	5
6	6D	1.240000	-.000700	1	6
7	7D	1.240000	-.000700	1	7
8	8D	1.240000	-.000700	1	8
9	9D	1.240000	-.000700	1	9
10	10D	1.240000	-.000700	1	10
11	11D	1.240000	-.000700	1	11
12	12D	1.240000	-.002300	1	12
13	1E	1.240000	-.002300	1	13
14	2E	1.240000	-.000700	1	14
15	3E	1.240000	-.000700	1	15
16	4E	1.240000	-.008300	1	16
17	5E	1.240000	-.008700	1	17
18	6E	1.240000	-.008300	1	18
19	7E	1.240000	-.008700	1	19
20	8E	1.240000	-.000700	1	20
21	9E	1.240000	-.002300	1	21
22	10E	1.240000	-.000700	1	22
23	11E	1.240000	-.002300	1	23
24	1F	1.240000	-.008700	1	24
25	2F	1.240000	-.008300	1	25
26	3F	1.240000	-.008700	1	26
27	4F	1.240000	-.002300	1	27
28	5F	1.240000	-.008700	1	28
29	6F	1.240000	-.008300	1	29
30	7F	1.240000	-.000700	1	30
31	8F	1.240000	.007300	1	31
32	9F	1.240000	-.002300	1	32
33	10F	1.240000	-.000700	1	33
34	11F	1.240000	.006000	1	34
35	1G	1.240000	-.008700	1	35
36	2G	1.240000	-.008700	1	36
37	3G	1.240000	.005500	1	37
38	4G	1.240000	.005500	1	38
39	5G	1.240000	-.008700	1	39
40	6G	1.240000	-.008700	1	40
41	7G	1.240000	.005500	1	41
42	8G	1.240000	.005500	1	42
43	1H	1.240000	-.008700	1	51
44	2H	1.240000	.005500	1	44
45	3H	1.240000	-.008700	1	45
46	4H	1.240000	-.008700	1	46
47	5H	1.240000	.005500	1	47
48	6H	1.240000	-.008700	1	48
49	7H	1.240000	.005500	1	49
50	8H	1.240000	.005500	1	50
51	1J	1.240000	-.008700	1	43
52	2J	1.240000	.005500	1	52
53	3J	1.240000	.005500	1	53
54	4J	1.240000	-.008700	1	54
55	5J	1.240000	-.008700	1	55
56	6J	1.240000	-.008700	1	56

KAERI/TR-2511/2003

57 7J 1.240000 .005500 1 57
 58 8J 1.240000 .005500 1 58

Reading Detector Readings

DETECTOR READING FOR DUPIC
 Reading 58 detectors of 58 sites available.
 Reading 232 cases of 232 available.
 Performing 7G with 3G compensation.
 Performing 8G with 4G compensation.
 Performing 2H with 5H compensation.
 Performing 7H with 8H compensation.
 Performing 2J with 3J compensation.
 Performing 8J with 7J compensation.

Performing Precalculation

reading cppf.data
 CPPF Data (DB_W1_DUP_0)

Average CPPF = 1.0681

reading rover-orif.data
 Nucirc Data (DB_W1_DUP_0)

Low Conservatism Channel Map Generated
 in file rover-lccm.output.
 Completed Precalculation

Results

Case	CPRL	Avg. Cons.	SDS1
Case SDS2 LimDets			
1 1 SSSC50 STEADY-STATE WITH S.C.	1.414206	1.028029	.999692
.999607 6D 3G			
2 2 SSSC20 STEADY-STATE WITH S.C.	1.395865	1.036093	.999797
.999491 4D 7J			
3 3 SSSC40 STEADY-STATE WITH S.C.	1.406428	1.032348	.999670
.999587 9D 7G			
4 4 SSSC60 STEADY-STATE WITH S.C.	1.412592	1.030130	.999727
.999631 7D 4G			
5 5 SSSC80 STEADY-STATE WITH S.C.	1.408862	1.026107	.999767
.999546 11D 3G			
6 6 SSNC10 STEADY-STATE WITHOUT S.C	1.389107	1.038523	.999853
.999337 4D 8H			
7 7 SSNC20 STEADY-STATE WITHOUT S.C	1.393898	1.037761	.999790
.999485 4D 7G			
8 8 SSNC80 STEADY-STATE WITHOUT S.C	1.391360	1.031004	.999734
.999296 11D 3G			
9 9 SSNC90 STEADY-STATE WITHOUT S.C	1.367126	1.030056	.999607
.998001 11D 2H			
10 10 D01C20 ZONE DRAIN 01 FROM 20%	1.377052	1.047484	.999707
.999405 4D 7J			
11 11 D02C20 ZONE DRAIN 02 FROM 20%	1.381608	1.044669	.999786
.999392 1E 7J			
12 12 D03C20 ZONE DRAIN 03 FROM 20%	1.401072	1.032172	.999829
.999553 1E 7J			
13 13 D04C20 ZONE DRAIN 04 FROM 20%	1.398209	1.031460	.999742
.999527 4D 7J			
14 14 D05C20 ZONE DRAIN 05 FROM 20%	1.401251	1.033608	.999782
.999467 4D 8H			
15 15 D06C20 ZONE DRAIN 06 FROM 20%	1.380699	1.045517	.999757
.999433 11D 7J			
16 16 D07C20 ZONE DRAIN 07 FROM 20%	1.382403	1.044872	.999766
.999490 4F 8H			
17 17 D08C20 ZONE DRAIN 08 FROM 20%	1.378235	1.046617	.999748
.999416 9D 8H			
18 18 D09C20 ZONE DRAIN 09 FROM 20%	1.379968	1.045677	.999743
.999396 4D 8H			
19 19 D10C20 ZONE DRAIN 10 FROM 20%	1.400977	1.032297	.999758
.999535 4F 8H			

KAERI/TR-2511/2003

20	20	D11C20	ZONE DRAIN 11 FROM 20%	1.397961	1.031610	.999769
.999545		4F 8H				
21	21	D12C20	ZONE DRAIN 12 FROM 20%	1.401111	1.033665	.999833
.999471		1E 7J				
22	22	D13C20	ZONE DRAIN 13 FROM 20%	1.379708	1.046367	.999744
.999465		12D 7J				
23	23	D14C20	ZONE DRAIN 14 FROM 20%	1.383986	1.043767	.999746
.999473		11D 7J				
24	24	D01C50	ZONE DRAIN 01 FROM 50%	1.361253	1.048300	.999142
.998901		5F 5G				
25	25	D02C50	ZONE DRAIN 02 FROM 50%	1.370617	1.043195	.999515
.998821		2E 3G				
26	26	D03C50	ZONE DRAIN 03 FROM 50%	1.394047	1.033045	.999620
.999558		6E 5J				
27	27	D04C50	ZONE DRAIN 04 FROM 50%	1.395797	1.029699	.999496
.999428		7D 7J				
28	28	D05C50	ZONE DRAIN 05 FROM 50%	1.400845	1.025726	.999525
.999061		4D 7J				
29	29	D06C50	ZONE DRAIN 06 FROM 50%	1.361760	1.051598	.999349
.999253		8E 1G				
30	30	D07C50	ZONE DRAIN 07 FROM 50%	1.368929	1.045871	.999291
.998762		4E 4G				
31	31	D08C50	ZONE DRAIN 08 FROM 50%	1.351563	1.050516	.998862
.999102		5E 2G				
32	32	D09C50	ZONE DRAIN 09 FROM 50%	1.366453	1.045382	.999287
.998846		9D 3H				
33	33	D10C50	ZONE DRAIN 10 FROM 50%	1.390649	1.034124	.999333
.999593		8E 6H				
34	34	D11C50	ZONE DRAIN 11 FROM 50%	1.396212	1.029354	.999511
.999549		11F 2H				
35	35	D12C50	ZONE DRAIN 12 FROM 50%	1.400824	1.025706	.999635
.999070		10E 8H				
36	36	D13C50	ZONE DRAIN 13 FROM 50%	1.363539	1.049519	.999281
.998970		9F 7H				
37	37	D14C50	ZONE DRAIN 14 FROM 50%	1.372773	1.043367	.999317
.998897		10E 4G				
38	38	D01C80	ZONE DRAIN 01 FROM 80%	1.315854	1.052419	.997377
.996684		5F 2H				
39	39	D02C80	ZONE DRAIN 02 FROM 80%	1.293773	1.040400	.999591
.990010		2E 2G				
40	40	D03C80	ZONE DRAIN 03 FROM 80%	1.364467	1.039226	.999456
.999120		8E 2J				
41	41	D04C80	ZONE DRAIN 04 FROM 80%	1.395829	1.027762	.999677
.999230		7D 2J				
42	42	D05C80	ZONE DRAIN 05 FROM 80%	1.287262	1.028766	.996570
.975111		4D 7J				
43	43	D06C80	ZONE DRAIN 06 FROM 80%	1.322822	1.052011	.998388
.998585		8E 1G				
44	44	D07C80	ZONE DRAIN 07 FROM 80%	1.287740	1.043119	.998230
.985932		9F 4H				
45	45	D08C80	ZONE DRAIN 08 FROM 80%	1.321406	1.051443	.997355
.998645		5E 6G				
46	46	D09C80	ZONE DRAIN 09 FROM 80%	1.285568	1.043843	.996776
.991792		6D 3H				
47	47	D10C80	ZONE DRAIN 10 FROM 80%	1.363646	1.039392	.998981
.999476		6F 2H				
48	48	D11C80	ZONE DRAIN 11 FROM 80%	1.395630	1.027605	.999641
.999730		10E 3G				
49	49	D12C80	ZONE DRAIN 12 FROM 80%	1.287278	1.028124	.998436
.974891		9E 8H				
50	50	D13C80	ZONE DRAIN 13 FROM 80%	1.318809	1.052684	.997691
.996780		9F 4H				
51	51	D14C80	ZONE DRAIN 14 FROM 80%	1.296551	1.039896	.996514
.991889		10E 4G				
52	52	D01N50	ZONE DRAIN 01 FROM 50%	1.325814	1.050498	.997843
.997819		1F 5G				
53	53	D02N50	ZONE DRAIN 02 FROM 50%	1.337646	1.045217	.999488
.997223		2E 3J				
54	54	D03N50	ZONE DRAIN 03 FROM 50%	1.368012	1.034919	.999339
.999555		1E 5J				
55	55	D04N50	ZONE DRAIN 04 FROM 50%	1.392386	1.031032	.999573
.999599		3D 7J				
56	56	D05N50	ZONE DRAIN 05 FROM 50%	1.370491	1.030885	.999321

KAERI/TR-2511/2003

.998788	4D 7J				
57 57	D06N50	ZONE DRAIN 06 FROM 50%	1.329980	1.051091	.998648
.998845	3E 1G				
58 58	D07N50	ZONE DRAIN 07 FROM 50%	1.332767	1.047279	.999205
.997700	3F 7H				
59 59	D08N50	ZONE DRAIN 08 FROM 50%	1.329111	1.049924	.997608
.998797	5E 6G				
60 60	D09N50	ZONE DRAIN 09 FROM 50%	1.331552	1.046805	.998800
.997231	6D 3H				
61 61	D10N50	ZONE DRAIN 10 FROM 50%	1.365883	1.035486	.998350
.999649	8E 6H				
62 62	D11N50	ZONE DRAIN 11 FROM 50%	1.392707	1.030721	.999615
.999750	11F 8H				
63 63	D12N50	ZONE DRAIN 12 FROM 50%	1.370404	1.030528	.999624
.998821	10E 8H				
64 64	D13N50	ZONE DRAIN 13 FROM 50%	1.327207	1.051348	.998006
.997810	9F 1G				
65 65	D14N50	ZONE DRAIN 14 FROM 50%	1.339731	1.045304	.998801
.998506	9F 2J				
66 66	AJFO01	ADJUSTER 01 FULL-OUT	1.410034	1.030928	.999704
.999635	12D 8G				
67 67	AJFO02	ADJUSTER 02 FULL-OUT	1.384712	1.039736	.999742
.999477	2F 3G				
68 68	AJFO03	ADJUSTER 03 FULL-OUT	1.383456	1.033341	.999580
.999151	1E 3J				
69 69	AJFO04	ADJUSTER 04 FULL-OUT	1.392627	1.036860	.999702
.999527	7D 7J				
70 70	AJFO05	ADJUSTER 05 FULL-OUT	1.385955	1.032506	.999920
.999331	3D 1H				
71 71	AJFO06	ADJUSTER 06 FULL-OUT	1.388980	1.036997	.999778
.999471	3E 2H				
72 72	AJFO07	ADJUSTER 07 FULL-OUT	1.411660	1.029542	.999702
.999629	3E 2H				
73 73	AJFO08	ADJUSTER 08 FULL-OUT	1.411462	1.029289	.999712
.999812	5D 3H				
74 74	AJFO09	ADJUSTER 09 FULL-OUT	1.383080	1.039716	.999784
.999763	5E 3J				
75 75	AJFO10	ADJUSTER 10 FULL-OUT	1.387114	1.031647	.999732
.999442	7E 3J				
76 76	AJFO11	ADJUSTER 11 FULL-OUT	1.391376	1.035501	.999844
.999630	6D 2J				
77 77	AJFO12	ADJUSTER 12 FULL-OUT	1.387850	1.031575	.999997
.999900	8E 2J				
78 78	AJFO13	ADJUSTER 13 FULL-OUT	1.385468	1.038651	.999972
.999752	8E 1H				
79 79	AJFO14	ADJUSTER 14 FULL-OUT	1.410839	1.029897	.999729
.999814	8E 4H				
80 80	AJFO15	ADJUSTER 15 FULL-OUT	1.414070	1.027965	.999708
.999664	9D 3H				
81 81	AJFO16	ADJUSTER 16 FULL-OUT	1.387398	1.037783	.999670
.999603	5F 8J				
82 82	AJFO17	ADJUSTER 17 FULL-OUT	1.384890	1.032941	.999580
.999682	9E 8J				
83 83	AJFO18	ADJUSTER 18 FULL-OUT	1.392854	1.036356	.999718
.999621	10E 8J				
84 84	AJFO19	ADJUSTER 19 FULL-OUT	1.385102	1.033115	.999758
.999608	8F 2J				
85 85	AJFO20	ADJUSTER 20 FULL-OUT	1.386716	1.038958	.999789
.999583	8F 1H				
86 86	AJFO21	ADJUSTER 21 FULL-OUT	1.412401	1.028529	.999762
.999652	9F 4G				
87 87	AJHO01	ADJUSTER 01 HALF-OUT	1.413713	1.028049	.999678
.999609	3E 3J				
88 88	AJHO02	ADJUSTER 02 HALF-OUT	1.393236	1.039224	.999710
.999586	2E 3J				
89 89	AJHO03	ADJUSTER 03 HALF-OUT	1.395192	1.034829	.999717
.999517	2F 3J				
90 90	AJHO04	ADJUSTER 04 HALF-OUT	1.397455	1.035694	.999730
.999549	6D 3J				
91 91	AJHO05	ADJUSTER 05 HALF-OUT	1.389832	1.037230	.999821

KAERI/TR-2511/2003

.999382	4D 2H				
92 92	AJHO06	ADJUSTER 06 HALF-OUT	1.391426	1.038601	.999738
.999482	3E 2H				
93 93	AJHO07	ADJUSTER 07 HALF-OUT	1.413311	1.028427	.999675
.999599	3E 4G				
94 94	AJHO08	ADJUSTER 08 HALF-OUT	1.414268	1.027557	.999711
.999644	10D 2J				
95 95	AJHO09	ADJUSTER 09 HALF-OUT	1.392035	1.038848	.999740
.999712	5E 3J				
96 96	AJHO10	ADJUSTER 10 HALF-OUT	1.391247	1.036841	.999691
.999548	8F 3J				
97 97	AJHO11	ADJUSTER 11 HALF-OUT	1.402522	1.027348	.999663
.999648	1F 6J				
98 98	AJHO12	ADJUSTER 12 HALF-OUT	1.391822	1.034479	.999876
.999465	7D 5H				
99 99	AJHO13	ADJUSTER 13 HALF-OUT	1.394739	1.036694	.999760
.999669	7E 4H				
100 100	AJHO14	ADJUSTER 14 HALF-OUT	1.412771	1.028656	.999682
.999626	1E 4G				
101 101	AJHO15	ADJUSTER 15 HALF-OUT	1.414759	1.027279	.999689
.999615	8E 3G				
102 102	AJHO16	ADJUSTER 16 HALF-OUT	1.393342	1.039483	.999734
.999678	10F 8J				
103 103	AJHO17	ADJUSTER 17 HALF-OUT	1.389099	1.039590	.999753
.999567	9E 3H				
104 104	AJHO18	ADJUSTER 18 HALF-OUT	1.397831	1.035169	.999694
.999550	10E 5H				
105 105	AJHO19	ADJUSTER 19 HALF-OUT	1.395955	1.032431	.999773
.999446	11D 8H				
106 106	AJHO20	ADJUSTER 20 HALF-OUT	1.395645	1.036986	.999767
.999615	11E 8H				
107 107	AJHO21	ADJUSTER 21 HALF-OUT	1.413633	1.028180	.999674
.999597	3E 3J				
108 108	MCAC1H	MCA 1ST BANK HALF-IN	1.290789	1.026019	.999303
.990789	2E 8J				
109 109	MCAC1F	MCA 1ST BANK FULL-IN	1.328571	1.031350	.999625
.999911	9D 5H				
110 110	MCAC2H	MCA 1ST FI & 2ND HI	1.168160	1.024127	.997186
.995469	2E 7H				
111 111	MCAC2F	MCA 1ST FI & 2ND HI	1.217153	1.037688	.997927
.999791	2E 8J				
112 112	MCAN1H	MCA 1ST BANK HALF-IN	1.172954	1.027881	.999304
.978490	11D 7H				
113 113	MCAN1F	MCA 1ST BANK FULL-IN	1.258388	1.041295	.999603
.999873	9D 5H				
114 114	MCAN2H	MCA 1ST FI & 2ND HI	1.102006	1.028476	.995134
.994428	11D 7H				
115 115	MCAN2F	MCA 1ST FI & 2ND FI	1.148860	1.041988	.995429
.999736	2E 8J				
116 116	MCAS1I	MCA ROD 01 STUCK-IN	1.295200	1.035216	.999301
.999389	11E 4H				
117 117	MCAS12	MCA ROD 02 STUCK-IN	1.293585	1.038309	.998963
.999379	5D 2H				
118 118	MCAS13	MCA ROD 03 STUCK-IN	1.295996	1.038131	.999452
.999332	11E 4H				
119 119	MCAS14	MCA ROD 04 STUCK-IN	1.293626	1.039588	.999275
.999461	9D 2G				
120 120	ZT1ATB	1ST AZIMUTHAL TOB/BOTTOM	1.283709	1.033527	.999690
.996461	10F 8H				
121 121	ZT1ABT	1ST AZIMUTHAL BOTTOM/TOP	1.271510	1.026232	.995749
.999252	1E 6J				
122 122	ZT5FSE	1ST AZIMUTHAL SIDE/SIDE	1.257559	1.045506	.997442
.996167	11E 1G				
123 123	ZT5ESF	1ST AZIMUTHAL SIDE/SIDE	1.255475	1.044012	.997591
.995215	1D 2G				
124 124	ZTEFEE	1ST AXIAL END/END	1.401662	1.032974	.999999
1.000000	9E 8H				
125 125	ZTEEEF	1ST AXIAL END/END	1.399796	1.035667	.999999
1.000000	4D 7J				

KAERI/TR-2511/2003

126	126	ZTT045	1ST AZIMUTHAL TOP AT 045	1.265897	1.049862	.999178
	.995696	1D 8G				
127	127	ZTT135	1ST AZIMUTHAL TOP AT 135	1.267906	1.048805	.998982
	.997482	7F 7G				
128	128	ZTT225	1ST AZIMUTHAL TOP AT 225	1.259769	1.038682	.996810
	.997754	11E 6G				
129	129	ZTT315	1ST AZIMUTHAL TOP AT 315	1.258256	1.036035	.995866
	.998567	1F 6H				
130	130	ZT2A01	2ND AZIMUTHAL 135,315 HI	1.313649	1.053683	.998990
	.996852	1D 2G				
131	131	ZT2A02	2ND AZIMUTHAL 045,225 HI	1.314865	1.053043	.998230
	.997950	9F 7G				
132	132	ZT2A03	2ND AZIMUTHAL T/B HI	1.388958	1.034597	.999486
	.999060	1D 1G				
133	133	ZT2A04	2ND AZIMUTHAL SIDES HI	1.365828	1.039449	.999747
	.998610	10F 8J				
134	134	ZTAX01	1ST AZIMUTHAL-AXIAL S=HI	1.407525	1.031624	.999913
	.999720	4D 7G				
135	135	ZTAX02	1ST AZIMUTHAL-AXIAL S=LO	1.407655	1.032008	.999896
	.999684	2F 8G				
136	136	ZTAX03	1ST AZIMUTHAL-AXIAL T=HI	1.410546	1.030756	.999976
	.999982	2F 7J				
137	137	ZTAX04	1ST AZIMUTHAL-AXIAL T=LO	1.408859	1.030814	.999982
	.999982	9E 8H				
138	138	ZT1R01	1ST RADIAL CENTER HI	1.378173	1.036713	.999670
	.999190	10F 7G				
139	139	ZT1R02	1ST RADIAL OUTER HI	1.340039	1.033573	.998181
	.997674	3F 7G				
150	150	SSSD01	ALL BANKS OUT/Xe @ 38.1 MIN	1.112423	1.030503	1.000000
	.999995	6E 4J				
151	151	SSSD02	ALL BANKS OUT/Xe @ 22.3 MIN	1.135780	1.027781	1.000000
	1.000000	7E 4J				
152	152	SSSD03	BANK 7 FULL-IN/NO TIMESTEP	1.228802	1.035893	1.000000
	.999999	7E 4J				
153	153	SSSD04	BANK 7 FULL-IN/Xe @ 27.4 MIN	1.113894	1.030107	1.000000
	1.000000	7E 4J				
154	154	SSSD05	BANK 6 FULL-IN/NO TIMESTEP	1.196461	1.031300	1.000000
	1.000000	7E 4J				
155	155	SSSD06	BANK 6 FULL-IN/Xe @ 26.7 MIN	1.196468	1.034696	1.000000
	1.000000	7E 4J				
156	156	SSSD07	BANK 5 FULL-IN/NO TIMESTEP	1.248258	1.037239	.999999
	1.000000	7E 4J				
157	157	SSSD08	BANK 5 FULL-IN/Xe @ 26.5 MIN	1.240090	1.028835	1.000000
	1.000000	7E 4J				
158	158	SSSD09	BANK 4 FULL-IN/NO TIMESTEP	1.268363	1.040234	.999997
	.999949	8F 4J				
159	159	SSSD10	BANK 4 FULL-IN/Xe @ 23.5 MIN	1.259796	1.038614	.999998
	.999956	8F 4J				
160	160	SSSD11	BANK 3 FULL-IN/NO TIMESTEP	1.314008	1.041007	.999991
	.999897	8F 4J				
161	161	SSSD12	BANK 3 FULL-IN/Xe @ 27.8 MIN	1.315019	1.040953	.999994
	.999943	7E 4J				
162	162	SSSD13	BANK 2 FULL-IN/NO TIMESTEP	1.367433	1.035510	.999971
	.999945	8F 4J				
163	163	SSSD14	BANK 2 FULL-IN/Xe @ 43.6 MIN	1.382607	1.035118	.999982
	.999982	8F 3J				
164	164	SSSD15	BANK 1 FULL-IN/NO TIMESTEP	1.408853	1.028469	.999866
	.999852	8E 3J				
165	165	SSSD16	BANK 1 FULL-IN/Xe @ 90.0 MIN	1.410949	1.028993	.999749
	.999657	2E 7H				
166	166	SSSD17	ALL BANKS IN/Xe @ 180. MIN	1.412881	1.028548	.999669
	.999541	2E 8G				
167	167	SSSD18	ALL BANKS IN/Xe @ 270. MIN	1.413801	1.028176	.999618
	.999517	2E 3J				
168	168	SA4400	ALL BANKS OUT/Xe @ 36. HRS	1.137859	1.039423	1.000000
	1.000000	5D 5G				
169	169	SA4401	ALL BANKS OUT/Xe @ 46.4 MIN	1.131681	1.039279	1.000000
	1.000000	5D 5G				
170	170	SA4402	ALL BANKS OUT/Xe @ 5.3 MIN	1.149626	1.030334	1.000000

KAERI/TR-2511/2003

1.000000	5D	5G					
171	171	SA4403	BANK 7 FULL-IN	1.258770	1.036599	1.000000	
1.000000	5D	5G					
172	172	SA4404	BANK 7 FULL-IN/Xe @ 5.2 MIN	1.250600	1.030813	1.000000	
1.000000	5D	5G					
173	173	SA4405	BANK 6 FULL-IN	1.337852	1.029127	1.000000	
1.000000	5D	5G					
174	174	SA4406	BANK 6 FULL-IN/Xe @ 4.3 MIN	1.280011	1.027317	1.000000	
1.000000	5D	5G					
175	175	SA4407	BANK 5 FULL-IN	1.327186	1.039727	1.000000	
1.000000	5D	5G					
176	176	SA4408	BANK 5 FULL-IN/Xe @ 4.3 MIN	1.320873	1.031073	1.000000	
1.000000	5D	5G					
177	177	SA4409	BANK 4 FULL-IN	1.347448	1.038562	1.000000	
1.000000	5D	5G					
178	178	SA4410	BANK 4 FULL-IN/Xe @ 3.9 MIN	1.336708	1.036986	1.000000	
1.000000	5D	5G					
179	179	SA4411	BANK 3 FULL-IN	1.384288	1.038033	1.000000	
1.000000	5D	5G					
180	180	SA4412	BANK 3 FULL-IN/Xe @ 3.9 MIN	1.380823	1.038784	1.000000	
1.000000	5D	5G					
181	181	SA4413	BANK 2 FULL-IN	1.415281	1.028021	1.000000	
1.000000	5D	5G					
182	182	SA4414	BANK 2 FULL-IN/Xe @4.2 MIN	1.424749	1.026058	1.000000	
1.000000	5D	5G					
183	183	SA4415	BANK 1 FULL-IN	1.433245	1.024055	1.000000	
1.000000	5D	5G					
184	184	SA4416	BANK 1 FI+0.5PPM/Xe @ 12.9 MIN	1.411156	1.031896	1.000000	
1.000000	5D	5G					
185	185	SA4417	ALL BANKS IN+2.0PPM/Xe @ 83.7 MIN	1.402547	1.034089	1.000000	
1.000000	5D	5G					
186	186	SA4418	ALL BANKS IN+2.0PPM/Xe @ 263.7MIN	1.385965	1.034848	1.000000	
1.000000	5D	5G					
191	191	SBCK01	ALL BANKS IN/Xe @ 12.3 MIN	1.401273	1.033895	.999768	
.999512	4D	7J					
192	192	SBCK02	BANK 1 OUT	1.391246	1.036443	.999808	
.999662	6F	3J					
193	193	SBCK03	BANK 1 OUT/Xe @ 10.5 MIN	1.395328	1.033065	.999803	
.999490	12D	7J					
194	194	SBCK04	BANK 2 OUT +	1.366580	1.037189	.999928	
.999597	7E	4J					
195	195	SBCK05	BANK 2 OUT/Xe @ 18.3 MIN	1.381141	1.032195	.999958	
.999420	4F	7J					
196	196	SBCK06	BANK 3 OUT	1.327088	1.038162	.999959	
.999610	6F	4J					
197	197	SBCK07	BANK 3 OUT/Xe @ 28.5 MIN	1.344294	1.033694	.999965	
.999566	4F	4J					
198	198	SBCK08	BANK 4 OUT	1.285447	1.041753	.999995	
1.000000	7E	4G					
199	199	SBCK09	BANK 4 OUT/Xe @ 310.9 MIN	1.264932	1.034191	.999999	
1.000000	7E	3G					
200	200	SBCK10	BANK 4 IN	1.299704	1.039732	.999988	
.999889	8F	4J					
201	201	SBCK11	BANK 4 IN/Xe @ 270.4 MIN	1.304405	1.036661	.999984	
.999770	6F	4J					
202	202	SHIM01	ALL BANKS IN/SS Xe	1.394837	1.036854	.999786	
.999492	4D	8H					
203	203	SHIM02	BANK 1 OUT	1.387573	1.036765	.999836	
.999716	6F	3J					
204	204	SHIM03	BANK 1 OUT/Xe @240. MIN	1.387928	1.035187	.999856	
.999606	4F	7J					
205	205	SHIM04	BANK 1 OUT/SS Xe	1.391536	1.034359	.999830	
.999567	12D	7J					
206	206	SHIM05	BANK 2 OUT	1.360741	1.037334	.999932	
.999656	7E	4J					
207	207	SHIM06	BANK 2 OUT/Xe A 240.MIN	1.369541	1.034565	.999961	
.999620	6F	4J					
208	208	SHIM07	BANK 2 OUT/SS Xe	1.377985	1.032737	.999957	
.999521	4F	7J					

KAERI/TR-2511/2003


209	209	SHIM08	BANK 3 OUT	1.325058	1.037840	.999964
.999703	6F	4J				
210	210	SHIM09	BANK 3 OUT/Xe @ 240. MIN	1.325789	1.037439	.999967
.999720	8F	4J				
211	211	SHIM10	BANK 3 OUT/SS Xe	1.345943	1.034005	.999960
.999599	4F	4J				
212	212	SHIM11	BANK 4 OUT	1.286884	1.042317	.999994
1.000000	8E	3G				
213	213	SHIM12	BANK 4 OUT/Xe @ 240.0 MIN	1.280175	1.043635	.999996
1.000000	8E	3G				
214	214	SHIM13	BANK 4 OUT/SS Xe	1.293748	1.043079	.999992
1.000000	11E	3G				
215	215	SHIM14	BANK 5 OUT	1.255189	1.035155	.999999
1.000000	10E	4J				
216	216	SHIM15	BANK 5 OUT/Xe @ 240.0 MIN	1.268748	1.035879	.999999
1.000000	10E	4J				
217	217	SHIM16	BANK 5 OUT/SS Xe	1.288158	1.031478	.999999
1.000000	10E	4J				
218	218	SHIM17	BANK 6 OUT	1.210067	1.033043	1.000000
1.000000	7E	4J				
219	219	SHIM18	BANK 6 OUT/SS Xe	1.237281	1.037271	1.000000
.999999	7E	4J				
220	220	SHIM19	BANK 7 OUT	1.148786	1.027506	1.000000
1.000000	6E	4J				
221	221	SHIM20	BANK 7 OUT/SS Xe	1.175407	1.034304	1.000000
.999999	7E	4J				
222	222	ABHO01	STARTUP BANK 7 HALF-IN	1.117708	1.036479	1.000000
1.000000	7E	4J				
223	223	ABHO02	STARTUP BANK 6 HALF-IN	1.109436	1.033655	1.000000
1.000000	7E	4J				
224	224	ABHO03	STARTUP BANK 5 HALF-IN	1.155840	1.043934	1.000000
1.000000	7E	3H				
225	225	ABHO04	STARTUP BANK 4 HALF-IN	1.192824	1.041239	.999999
1.000000	7E	3H				
226	226	ABHO05	STARTUP BANK 3 HALF-IN	1.206773	1.044020	.999981
.999762	5D	4J				
227	227	ABHO06	SHIM BANK 1 HALF-OUT	1.343868	1.036276	.999715
.998311	10F	8H				
228	228	ABHO07	SHIM BANK 2 HALF-OUT	1.288599	1.041409	.999792
.998419	7E	7H				
229	229	MCASH1	MCA ROD 1 HALF-IN	1.372097	1.034713	.999745
.999376	2E	1G				
230	230	MCASH2	MCA ROD 2 HALF-IN	1.372872	1.032033	.999626
.999436	2E	3J				
231	231	MCASH3	MCA ROD 3 HALF-IN	1.375121	1.033641	.999772
.999162	7F	1G				
232	232	MCASH4	MCA ROD 4 HALF-IN	1.371038	1.031761	.999557
.999285	2E	8H				
25 Worst Cases.						
49	D12C80	ZONE DRAIN 12 FROM 80%		.9984		.9749
42	D05C80	ZONE DRAIN 05 FROM 80%		.9966		.9751
112	MCAN1H	MCA 1ST BANK HALF-IN		.9993		.9785
44	D07C80	ZONE DRAIN 07 FROM 80%		.9982		.9859
39	D02C80	ZONE DRAIN 02 FROM 80%		.9996		.9900
108	MCAC1H	MCA 1ST BANK HALF-IN		.9993		.9908
46	D09C80	ZONE DRAIN 09 FROM 80%		.9968		.9918
51	D14C80	ZONE DRAIN 14 FROM 80%		.9965		.9919
114	MCAN2H	MCA 1ST FI & 2ND HI		.9951		.9944
123	ZTSESF	1ST AZIMUTHAL SIDE/SIDE		.9976		.9952
115	MCAN2F	MCA 1ST FI & 2ND FI		.9954		.9997
110	MCAC2H	MCA 1ST FI & 2ND HI		.9972		.9955
126	ZTT045	1ST AZIMUTHAL TOP AT 045		.9992		.9957
121	ZT1ABT	1ST AZIMUTHAL BOTTOM/TOP		.9957		.9993
129	ZTT315	1ST AZIMUTHAL TOP AT 315		.9959		.9986
122	ZTSPSE	1ST AZIMUTHAL SIDE/SIDE		.9974		.9962
120	ZT1ATB	1ST AZIMUTHAL TOB/BOTTOM		.9997		.9965
38	D01C80	ZONE DRAIN 01 FROM 80%		.9974		.9967
50	D13C80	ZONE DRAIN 13 FROM 80%		.9977		.9968

KAERI/TR-2511/2003

128	ZTT225	1ST AZIMUTHAL TOP AT 225	.9968	.9978
130	ZT2A01	2ND AZIMUTHAL 135,315 HI	.9990	.9969
53	D02N50	ZONE DRAIN 02 FROM 50%	.9995	.9972
60	D09N50	ZONE DRAIN 09 FROM 50%	.9988	.9972
45	D08C80	ZONE DRAIN 08 FROM 80%	.9974	.9986
127	ZTT135	1ST AZIMUTHAL TOP AT 135	.9990	.9975

Minimum trip confidence = .9749 for case 49

Calculating Required Setpoint Adjustment
Setpoint Adjustment = .9948 (.9800) Case : 49
Base Setpoint Result = 1.2336



서 지 정 보 양 식					
수행기관보고서번호	위탁기관보고서번호	표준보고서번호	INIS 주제코드		
KAERI/TR-2511/2003					
제목/부제	DUPIC 핵연료장전 중수로의 국부과출력 보호계통 해석				
연구책임자 및 부서명 (TR, AR인 경우 주저자)	정 창 준 (건식재가공핵연료 노심특성평가 기술개발)				
연구자 및 부서명	최 항 복 (건식재가공핵연료 노심특성평가 기술개발) 박 지 원 (건식재가공핵연료 노심특성평가 기술개발)				
출판지	대전	발행기관	한국원자력연구소	발행년	2003.6
페이지	63 p.	도표	있음(o), 없음()	크기	26 Cm.
참고사항					
비밀여부	공개(o), 대외비(), — 급 비밀, 소내만 공개()		보고서종류	기술보고서	
연구위탁기관			계약번호		
초록 (15-20줄내외)	<p>DUPIC 핵연료가 장전된 CANDU 6 원자로의 과출력 보호계통에 대한 평가를 수행하였다. 본 계산에는 WIMS/RFSP/ROVER-F 코드 체계에 대한 타당성 계산도 포함되었다. 타당성 계산 결과, WIMS/RFSP/ROVER-F 코드 체계는 CANDU 6 원자로의 과출력 보호 계통 해석에 대해 타당성을 갖는 것으로 나타났다. DUPIC 핵연료가 장전된 노심의 ROP 트립 설정치는 125.7%로 나타났으며, 이는 천연 우라늄 핵연료 장전 노심의 트립 설정치와 거의 유사하다. 본 연구는 DUPIC 핵연료의 장전이 천연 우라늄 핵연료 장전 노심에 대해 설계된 국부 과출력 트립 설정치에 영향을 미치지 않음을 보여준다.</p>				
주제명키워드 (10단어내외)	ROP 계통, CANDU 6 원자로, DUPIC 핵연료, 트립설정치, 오차, 불확실도, 계측기, 원자로 정지계통				

BIBLIOGRAPHIC INFORMATION SHEET					
Performing Org. Report No.		Sponsoring Org. Report No.		Standard Report No.	
KAERI/TR-2511/2003					
Title/Subtitle		Regional Overpower Protection System Analysis for a DUPIC Fuel CANDU Core			
Project Manager and Department		Chang-Joon Jeong (Dry-processed fuel core characteristics assessment technology development)			
Researcher and Department		Hangbok Choi Jee Won Park			
Publication Place	Taejon	Publisher	KAERI	Publication Date	2003.6
Page	63 p.	Ill. & Tab.	Yes(o), No (-)	Size	26 Cm.
Note					
Classified	Open(o), Restricted(), __Class Document, Internal Only ()		Report Type	Technical Report	
Sponsoring Org.		Contract No.			
Abstract (15-20 Lines)		<p>The regional overpower protection (ROP) system was assessed a CANDU 6 reactor with the DUPIC fuel, including the validation of the WIMS/RFSP/ROVER-F code system used for the estimation of ROP trip setpoint. The validation calculation has shown that it is valid to use the WIMS/RFSP/ROVER-F code system for ROP system analysis of the CANDU 6 core. For the DUPIC core, the ROP trip setpoint was estimated to be 125.7%, which is almost the same as that of the standard natural uranium core. This study has shown that the DUPIC fuel does not hurt the current ROP trip setpoint designed for the natural uranium CANDU 6 reactor.</p>			
Subject Keywords (About 10 words)		ROP System, CANDU 6 Reactor, DUPIC Fuel, Trip Setpoint, Error, Uncertainty, Detector, Shutdown System			